

**BEFORE THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF CALIFORNIA**

In the matter of the Application of  
San Diego Gas & Electric Company  
(U 902-E) for a Certificate of Public  
Convenience and Necessity for the  
Sunrise Powerlink Transmission  
Project

Application No. 06-08-010  
(Filed August 4, 2006)

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
FIRE ANALYSIS – ECONOMIC IMPACTS**

Diane Conklin, Spokesperson  
Mussey Grade Road Alliance  
P.O. Box 683  
Ramona, CA 92065  
Telephone: (760) 787-0794  
Facsimile: (760) 788- 5479  
Email: [dj0conklin@earthlink.net](mailto:dj0conklin@earthlink.net)

Dated: May 31, 2007

1 **TABLE OF CONTENTS**

2

3 1. INTRODUCTION AND TESTIMONY SUMMARY..... 1

4 2. SUNRISE POWERLINK AND WILDAND FIRES..... 2

5 3. SDG&E FIRE HISTORY ..... 3

6 4. WIND AND TRANSMISSION LINE OUTAGES..... 9

7 5. WIND AND WILDLAND FIRES..... 12

8 6. POWERLINE FIRES..... 16

9 7. FUEL LOAD HAZARD ALONG THE SUNRISE POWERLINK ROUTE ..... 20

10 8. WIND EXPOSURE OF POTENTIAL SPL ROUTES ..... 26

11 9. EFFECT OF SANTA ANA WINDS ON SUCCESS OF FIRE SUPPRESSION.... 29

12 10. LIABILITY DUE TO LOSSES FROM POWER LINE FIRES ..... 32

13 11. ECONOMIC IMPACTS OF WILDLAND FIRE – PROPERTY DAMAGE..... 36

14 12. COST/BENEFIT IMPACTS FROM PROPERTY DAMAGE ..... 39

15 13. COST/BENEFIT IMPACTS OF HABITAT RESTORATION ..... 41

16 14. OTHER WILDLAND FIRE ISSUES TO BE REVIEWED ..... 47

17 15. OTHER ISSUES TO BE REVIEWED..... 50

18

19 **APPENDICES AND ATTACHMENTS**

20

21 FILE	22 CONTENTS
23 MGRA_Mbar_SPL_AppA_Outages.pdf	App. A - Outages & Wind
24 MGRA_Mbar_SPL_AppB_SDGEFire.pdf	App. B – SDG&E Fire History
25 MGRA_Mbar_SPL_AppC_WindFire.pdf	App. C – Wind & fires
26 MGRA_Mbar_SPL_AppD_PowerLineFires.pdf	App. D – Power line fires
27 MGRA_Mbar_SPL_AppE_Vegetation.pdf	App. E - Vegetation
28 MGRA_Mbar_SPL_AppF_SAWind.pdf	App. F – Santa Ana Winds

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

**APPENDICES AND ATTACHMENTS (CONTINUED)**

FILE	CONTENTS
MGRA_Mbar_SPL_AppG_Liability.pdf	App. G - Liability
MGRA_Mbar_SPL_AppH_Costs.pdf	App. H – Costs
MGRA_Mbar_SPL_AppI_References.pdf	App. I - References
MGRA_Mbar_SPL_AppJ_CV.pdf	App. J - Vitae
MGRA_Mbar_SPL_Attachments.zip	Data in spreadsheet format

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 1 of 67**

1 **1. INTRODUCTION AND TESTIMONY SUMMARY**

2

3 **Q. Please state your name, address, company and qualifications.**

4 **A.** My name is Dr. Joseph W. Mitchell. I live at 19412 Kimball Valley Road,  
5 Ramona, CA 92065. I am the principal of M-bar Technologies and Consulting,  
6 also in Ramona, CA. My qualifications are provided in Appendix J<sup>1</sup> of this  
7 testimony.

8

9 **Q. On whose behalf are you submitting this testimony?**

10 **A.** I am submitting this testimony on behalf of the Mussey Grade Road  
11 Alliance.

12

13 **Q. What is the purpose of your testimony?**

14 **A.** The overall purpose of this Phase 1 testimony is to lay the foundation for,  
15 describe, and document the risk of wildland fire ignition with respect to San  
16 Diego Gas & Electric's (SDG&E) proposed Sunrise Powerlink Transmission  
17 Project (SPL) and to estimate the effects on the project in terms of the  
18 unanticipated costs of the SPL as a result of potential liability due to the ignition  
19 and consequences of wildland fire events.

20

21 **Q. What is the summary of your testimony regarding the economics  
22 of the proposed Sunrise Powerlink Project?**

23 **A.** The Mussey Grade Road Alliance's primary testimony is that, according  
24 to this analysis, negative public health and safety impacts as well as large  
25 unanticipated costs to the public, public lands, and ratepayers may occur due to  
26 one or more wildland fires accidentally ignited by normal operation and

---

<sup>1</sup> Attached as MGRA\_Mbar\_SPL\_AppJ\_CV.pdf

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 2 of 67**

1 maintenance of San Diego Gas & Electric Company’s (SDG&E) proposed  
2 Sunrise Powerlink Transmission Project (SPL) during the lifetime of the project.  
3 Ignition of fires during the lifetime of the project has been determined to be not  
4 unlikely, and the probability that these will be destructive fires causing significant  
5 damage is not small, though uncertainties in these estimates are large. These  
6 potential costs, weighted by likelihood, should be added to the cost/benefit  
7 analysis for this project.

8

9 **Q. What is the scope of this testimony?**

10 **A.** This testimony is intended to apply to any route that is considered as a  
11 potential route for the Sunrise Powerlink. Many of the analyses herein have been  
12 applied specifically to the original “preferred” route proposed by SDG&E,  
13 referred to as “the proposed route” in this testimony and supporting  
14 documentation. The methods and techniques used to gauge wildland fire risks that  
15 have been applied to this route should likewise be applied to any alternative route  
16 being considered as part of the EIR. These methods have been described in detail  
17 in the supporting documentation, and supporting data have also been provided as  
18 an example.

19

20 **2. SUNRISE POWERLINK AND WILDAND FIRES**

21

22 **Q. What is the most likely scenario in which the proposed project would**  
23 **initiate a catastrophic wildland fire?**

24 **A.** The conditions that lead to catastrophic power line fires are generally as  
25 follows:

- 26 1) A section of transmission line, tower, or other hardware is unusually  
27 vulnerable due to aging, material defects, assembly defects, poor maintenance,  
28 or exposure to unusually extreme conditions.

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 3 of 67**

- 1           2) This section of transmission line, tower, or other hardware is also in the  
2           proximity of flammable vegetation.
- 3           3) Weather conditions with strong gusting winds and low humidity (i.e. ‘Santa  
4           Ana’ conditions) are present.
- 5           4) Stress from the wind causes a component failure.
- 6           5) The component failure causes arcing and the ejection of hot or flaming  
7           materials.
- 8           6) The hot or burning materials ignite the adjacent vegetation.
- 9           7) The fire is rapidly spread due to the high wind and low moisture conditions.
- 10          8) Remoteness of the site or the rapid growth of the fire foils initial firefighting  
11          response, and the fire grows to a large size.
- 12

13 **3. SDG&E FIRE HISTORY**

14           **Q.     Should the proposed project be expected to generate wildland fires?**

15           **A.**     Probably. Based on historical fire data collected by SDG&E, we predict a  
16           rate of one induced fire per 20 years along the 230 kV segment of the proposed  
17           SPL route, with a 90% confidence level of statistical uncertainty ranging from 1  
18           per 200 years to 1 every 4 years. Under the hypothesis that the fire rates for 500  
19           kV and 230 kV lines are expected to be the same, this rate increases to every 15  
20           years, with the uncertainties adjusted by the same ratio.

21

22           **Q.     How were these probabilities determined?**

23           **A.**     The full analysis from which these numbers are derived can be found in  
24           Appendix B<sup>2</sup>. Fire data was provided to the Alliance by SDG&E for the period  
25           February 2004 to December 2006. Prior to 2004, SDG&E did not collect data on  
26           fire. This data was analyzed to determine a general rate of fires occurring due to

---

<sup>2</sup> Attached as MGRA\_Mbar\_SPL\_AppB\_SDGEFire.pdf

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 4 of 67**

1 or involving power lines. SDG&E has provided us with the lengths of  
2 transmission lines of various voltages within their network, and these can be used  
3 to determine a fire rate per mile of transmission line. These numbers can then be  
4 extrapolated for the proposed SPL project.

5

6 **Q. Is detailed location information included in the data provided by**  
7 **SDG&E?**

8 **A.** No, and according to SDG&E’s response to data request MGRA-10, no  
9 such data exists. This is despite the following entry in the Power Line Fire  
10 Prevention Field Manual, of which SDG&E was a co-author<sup>3</sup>: “Critical to the  
11 prevention of fires caused by electrical power is knowing when and where they  
12 occur and building this information into a GIS database which is shared by the  
13 fire agencies and electric utilities for future models and projects.”

14

15 **Q. How many fires were recorded in the SDG&E records?**

16 **A.** Eighty seven fires were recorded by SDG&E over a 35-month period.

17

18 **Q. How large were these fires?**

19 **A.** The majority of the fires were small, less than .1 acre. Total area burned  
20 by all fires was 352 acres.

21

22 **Q. What characterized the largest fires?**

23 **A.** Fires for which wind was recorded as a contributor were much larger than  
24 other fires, as indicated in Table B-1 in Appendix B, shown below:

25

---

<sup>3</sup> OSFM, CDF, USFS, PG&E, SC Edison, SDG&E; Power Line Fire Prevention Field Guide; Mar 27, 2001, p. 1-2

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

	<b>No wind</b>	<b>Wind</b>
<b>Acres burned (total)</b>	<b>52.1</b>	<b>300.3</b>
<b>Number of fires</b>	<b>80</b>	<b>7</b>
<b>Average size (acres)</b>	<b>0.65125</b>	<b>42.9</b>
<b>Median size (acres)</b>	<b>0.1</b>	<b>2</b>

1

2       It can be seen that both average and median fire sizes were much larger for the  
3       seven wind-related fires.

4

5       **Q.     Did any of these fires put lives or property at risk?**

6       **A.**     Yes. The Open fire of December 2006 near Santa Ysabel and not far from  
7       the proposed SPL route required an extremely aggressive and risky attack by  
8       firefighters to control it, reportedly described as “kamikaze” by one Division  
9       Chief who led the operation<sup>4</sup>. This was deemed necessary because of the very  
10      windy and dry conditions, and the proximity of the fires to 25,000 acres of  
11      unburned vegetation which would have carried the fire into the town of Ramona  
12      had it escaped initial attack.

13

14      **Q.     How many fires were caused by or related to transmission lines?**

15      **A.**     Nine fires were related to transmission lines in the 35-month period  
16      studied.

17

18      **Q.     How many miles of transmission lines are in the SDG&E service**

---

<sup>4</sup> Jones, J. Harry and Kristina Davis; Downed power line blamed for morning blaze that burned almost 300 acres in Santa Ysabel; San-Diego Union Tribune; Dec. 1, 2006.



**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1        **area?**

2        **A.**     According to SDG&E’s response to data request MGRA-18, the length  
3        and type of transmission lines in their service area is given below:

4                *Total transmission line lengths in the SDG&E service area:*

69 kV	884.2 mi.
230 kV	387.1 mi.
500 kV	158.2 mi.

5

6        **Q.**     **What is the rate of fires per mile of transmission line?**

7        **A.**     This gives a raw rate of 3.1 fires per year. According the table, the total  
8        length of transmission lines in the SDG&E service area is 1,430 miles, yielding a  
9        fire probability rate of .0022 fires yr<sup>-1</sup> mi<sup>-1</sup>.

10

11       **Q.**     **What were the causes of the transmission line fires?**

12       **A.**     Causes of SDG&E transmission line failures are summarized in the table  
13       below. Details are summarized in Appendix B<sup>5</sup>.

14

15

16

17

18

19

20

21

22

---

<sup>5</sup> Appendix B, Table B-3. Summary of transmission line fires.

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

<b>Cause</b>	<b>Events</b>	<b>Rate (yr<sup>-1</sup>mi<sup>-1</sup>)</b>
Human (maintenance, vandalism)	2	4.8e-4
Kites & balloons	3	7.2e-4
Equipment failure	2	4.8e-4
Wind-induced failure	2	4.8e-4

1       **Q.     How many of these fires were caused by 230 kV and 500 kV**  
2       **transmission lines?**

3       **A.     One fire, a December 2006 fire at Camp Pendleton that burned three**  
4       **acres, was caused by a 230 kV downed line, with the cause given as wind. If this**  
5       **number of events is typical of the expected rate, then one would expect .0009 fires**  
6       **per year per mile from 230 kV transmission lines. Statistical uncertainties on this**  
7       **number give us a statistical 90% confidence interval of .00009 to .0043 events per**  
8       **mile per year. No fires were caused by 500 kV lines.**

9

10       **Q.     How are uncertainties in rates be estimated?**

11       **A.     This is more fully described in Appendix B<sup>6</sup>. Expected rates are**  
12       **determined by assuming that the observed number of events is equal to the**  
13       **expected rate. To determine confidence intervals, an expected rate is calculated**  
14       **that would yield the observed number or less 5% of the time according to a**  
15       **Poisson distribution, which is used for the statistics of small numbers. The same is**

---

<sup>6</sup> Appendix B, Sec. 2.2.5. Transmission Line Fires / Limitations. Attached as  
MGRA\_Mbar\_SPL\_AppB\_SDGEFire.pdf

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 8 of 67**

1 done at the opposite end of the distribution to get the lower range.

2

3 **Q. Assuming that this fire rate is typical of that which would be expected**  
4 **for the SPL, how often might fires be expected?**

5 **A.** Assuming a 54 mile 230 kV segment of the line, a rate of .05 per year, or  
6 one fire per 20 years, would be expected. Statistical uncertainties would range  
7 from 1 per 4 to 1 per 200 years, with the wide range arising from the low  
8 statistics. If the 500kV line has the same fault rate as the 230 kV line, then this  
9 number would be expected to be 1 per 15 years.

10

11 **Q. What factors make SPL more or less likely to experience a significant**  
12 **fire than this estimate?**

13 **A.** A large fraction of the SPL route, and the vast majority of the 230 kV  
14 segment, traverses highly flammable vegetation, while other transmission lines  
15 may be more concentrated more in developed areas of the County. This would  
16 INCREASE the relative fire risk for SPL.

17 If the fire season increases in length due to climate change as suggested by  
18 Westerling<sup>7</sup>, this would INCREASE the number of fires expected.

19 If the path of the SPL is more exposed to extreme winds and Santa Ana  
20 conditions than other lines in the transmission network, this would INCREASE  
21 the number of fires expected<sup>8</sup>.

22 If the period examined was unusually mild in the number of wind events  
23 experienced, this would INCREASE the number of fires expected.

---

<sup>7</sup> Westerling, A. L., et al.; Warming and Earlier Spring Increase Western U.S. Forest Wildfire Activity; Science; v. 313; pp. 940-943; 18 Aug 2006

<sup>8</sup> See Appendices C and F.

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 9 of 67**

1           One might reasonably expect that the remoteness of the line from population  
2           centers will DECREASE the probability of fires induced by kites or Mylar  
3           balloons.

4           Changes in construction materials and line components in the future can either  
5           DECREASE fire probability (through advances in technology) or INCREASE fire  
6           probability (through use of less expensive materials with potentially higher defect  
7           rates to reduce operating costs).

8

9           **Q.     How would including the 500 kV line segment change these estimates?**

10          **A.**     Only about 20 miles of the 500 kV line segment traverse significantly  
11          hazardous vegetation. If we were to assume that the fault rate for 500 kV lines is  
12          the same as that for 230 kV lines, this would increase the expected rate to 1  
13          every 15 years.

14

15          **4. WIND AND TRANSMISSION LINE OUTAGES**

16

17          **Q.     Is the period for which SDG&E has been collecting fire data typical**  
18          **regarding extreme wind events?**

19          **A.**     No. In response to data requests MGRA-17 and MGRA-32, SDG&E has  
20          provided an outage history for lines of 69 kV or higher. This response was  
21          analyzed in Appendix A<sup>9</sup>, and compared against wind data. This analysis  
22          indicates that wind events causing multiple outages were observed in 2002-2003,  
23          but none have been observed since.

24

25          **Q.     How do we know which outages are caused by wind?**

---

<sup>9</sup> Appendix A – Power line Outages and Wind

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 10 of 67**

1           **A.**     SDG&E characterizes each outage with a cause, if the cause is known, or  
2 specifies it as “Undetermined” if no cause has been found. “Wind” is given as a  
3 cause for line outages.

4

5           **Q.**     **How many wind-caused outages were observed?**

6           **A.**     Fourteen wind events were observed over 9 years, causing a total of 126  
7 outages. Six of these events attributed to wind caused a single outage; two caused  
8 a double outage, while the remaining 6 events were responsible for the 117  
9 remaining outages. Of these, two events were responsible for a majority of the  
10 outages.

11           A wind storm from 2/9/02 to 2/10/02 caused 51 outages, and one on 3/29/03 was  
12 responsible for 42 outages.

13

14           **Q.**     **Can wind cause catastrophic failure of 230 kV or 500 kV towers?**

15           **A.**     Yes. Over the past year, there have been two catastrophic failures of high-  
16 tension towers in California, one in the SCE<sup>10</sup> and one in the PGE<sup>11</sup> service areas.  
17 The SCE tower was a 500 kV tower. Both of these failures were reportedly  
18 caused by high winds.

19

20           **Q.**     **How is the severity of wind events determined?**

21           **A.**     As described in Appendix A<sup>12</sup>, historical data was analyzed for three  
22 weather stations around the County, and this was compared to line outage data.

23           The maximum gust speed within 12 hours of the outage time (or outage window

---

<sup>10</sup> Queen, Rolla; Weather Topples Powerline Tower; BLM California; News Bytes; 238; July 5, 2006; available at

[http://www.blm.gov/ca/news/newsbytes/xtra-06/238-xtra\\_tower.html](http://www.blm.gov/ca/news/newsbytes/xtra-06/238-xtra_tower.html)

<sup>11</sup> Manekin, Michael; PG&E Tower Topples in Redwood City; Oakland Tribune; Dec. 28, 2006; available at

<http://www.builderonline.com/industry-news.asp?sectionID=96&articleID=415186>

<sup>12</sup> Appendix A – Section A2.1.4

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 11 of 67**

1 for multiple outages) was used. Two metrics were obtained: in one, the maximum  
2 gust speed for the three stations was averaged, and in the other the maximum was  
3 recorded.

4

5 **Q. What stations were used, and how were these determined?**

6 **A.** Stations were selected based upon good historical quality of data and the  
7 wide geographic dispersal. Stations at Julian, Potrero, and Camp Pendleton were  
8 chosen. These are displayed as AMO, POT, and JUL in the map in Figure A-1<sup>13</sup>.

9

10 **Q. How does the weather station data characterize the SDG&E wind**  
11 **outages?**

12 **A.** For the 14 wind events categorized by SDG&E, good weather station data  
13 was available for eight of them. Of these eight events, five were correlated with  
14 dry “Santa Ana” conditions, including the two largest events responsible for most  
15 outages. The remaining three events were wet winter storms. One dramatic result  
16 is shown in Figure A-2<sup>14</sup>. This demonstrates that the number of outage events  
17 shows a distinct correlation with the wind gust metrics above, with a somewhat  
18 better correlation for the average rather than the maximum. This correlation, as  
19 characterized by the average, shows a threshold wind speed at around 30 mph  
20 before outages begin to appear, with a very rapid rise up to the maximum of 49  
21 mph measured, which produced the 51 outage event. The trend for the maximum  
22 is similar, but shifted upwards by 5 mph or so. A very approximate  
23 parameterization of this relationship by a power law would have the equation  $N =$   
24  $(S - 29mph)^{1.5}$ , where  $S$  is the wind speed in mph and  $N$  is the number of outages.

25

26 **Q. Are the SDG&E characterizations of wind-induced outages accurate?**

---

<sup>13</sup> Appendix A, p. 5

<sup>14</sup> Appendix A, p. 7

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 12 of 67**

1           **A.**     With two exceptions, SDG&E has characterized all wind events leading to  
2 line outages correctly and completely. This was determined by examining clusters  
3 of outages which were not classified as wind-induced and for which the cause was  
4 not well determined. One of these correlated with a wind event as determined by  
5 weather station data. All outage data was also examined for 230 kV and 500 kV  
6 lines, which showed no excess outages during SDG&E reported wind events.  
7 Only one event was observed, and this was the one causing the Camp Pendleton  
8 fire of December 2006. Weather station data classifies this event as having  
9 borderline significance, but the fire record from SDG&E classifies it as a wind  
10 event.

11

12           **Q.**     **How do wind-induced faults and outages relate to fires?**

13           **A.**     According to the Power Line Fire Prevention Field Guide<sup>15</sup>, line  
14 separation or materials coming in contact with the line and causing faults are  
15 likely to cause arcing and the ejection of hot or burning materials. While safety  
16 measures are taken to prevent this occurrence, SDG&E does not maintain that  
17 these are adequate to prevent arcing, as they state in their response to data request  
18 MGRA-9. The Power Line Field Guide also notes that fires caused by power  
19 lines tend to be particularly dangerous because the same wind that causes the fault  
20 and ignition to occur will make it more likely that a large fire will be produced.

21

22           **5. WIND AND WILDLAND FIRES**

23

24           **Q.**     **What is the relationship between wind and wildland fires?**

25           **A.**     It is widely acknowledged that winds, particularly the dry easterly ‘Santa  
26 Ana’ winds of Southern California cause rapid spread of fires through wildland

---

<sup>15</sup> OSFM, CDF, USFS, PG&E, SC Edison, SDG&E; Power Line Fire Prevention Field Guide; Mar 27, 2001

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 13 of 67**

1 fuels. These usually occur in the autumn and winter, after the long dry season has  
2 desiccated vegetation. They are initiated by a high pressure system over the  
3 western US and a low pressure system off of the coast. This causes an easterly  
4 wind, and as this wind drops from the high plateaus and mountains it is  
5 compressed and heated, further lowering the humidity. It is further accelerated as  
6 it is funneled through valleys.

7 Moritz<sup>16</sup> has analyzed the relationship between extreme weather events and the  
8 size of wildland fires in the Los Padres National Forest, which is characterized by  
9 chaparral communities. He finds that “Comparing distributions of an index for  
10 severity of Santa Ana conditions (i.e., characterized by hot, dry winds) and  
11 extreme fire events in the Main Division [of the National Forest] indicated a  
12 convergence of distributions with increasing event size. The distribution of fire  
13 events larger than >4000 ha appears to be coupled with that of severe Santa Ana  
14 conditions, suggesting a strong climatic forcing for extreme fires and a threshold  
15 for the transition from small- to large-fire dynamics.”

16

17 **Q. What is the impact of large fires compared to that of small fires?**

18 **A.** Large, catastrophic wildland fires are responsible for the vast majority of  
19 area burned, and for number of homes lost. The change wrought by wildland fire  
20 is predominated by rare large events, rather than the accumulation of change by  
21 many smaller events. For instance, the 2003 Cedar fire burned more homes than  
22 the U.S. total wildland fire losses for 1999-2002 combined<sup>17</sup>. This sort of  
23 relationship is preserved as one looks at shorter time scales as well.

24

---

<sup>16</sup> Moritz, M. A.; ANALYZING EXTREME DISTURBANCE EVENTS: FIRE IN LOS PADRES NATIONAL FOREST; (1997) Ecol. Appl. 7, 1252–1262

<sup>17</sup> Mitchell, Joseph W.; Wind-enabled ember dousing; Fire Safety Journal; Volume 41, Issue 6, September 2006, Pages 444-458



**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 14 of 67**

1           **Q.     Are the reasons for this relationship between large and small fires**  
2           **understood?**

3           **A.**     Probably. Classes of models coming out of complexity theory suggest that  
4           power-law relationships dominated by large events will dominate statistics. In the  
5           theory of ‘self-organized criticality’, a model suggested for forest fires was found  
6           to actually match the measured distribution of forest fire sizes<sup>18</sup>. More recently  
7           another class of models based on the theory of “Highly Optimized Tolerance” was  
8           used by Moritz and others to compare against fire sizes in the Los Padres National  
9           Forest<sup>19</sup>. These were also compared against a deterministic fire spread model  
10          which used randomly generated fire starting points to predict a size distribution.  
11          The models assumed that the trigger occurred during a four-day Santa Ana event,  
12          and that there was an attempt at fire suppression. The researchers found an  
13          extremely close match in the fire size distributions between the model from  
14          complexity theory, the model from fire modeling, and the actual fire size data  
15          from the Los Padres National Forest. What this implies is that large catastrophic  
16          fires can be expected to dominate economic and ecological losses based upon  
17          relatively simple assumptions which include the presence of strong dry wind  
18          conditions. These are described in more detail in Appendix C<sup>20</sup>.

19  
20          **Q.     What is the relation between catastrophic wind-driven fires and**  
21          **economic loss through the destruction of homes and businesses?**

22          **A.**     Catastrophic, wind-driven fires are especially destructive because they are  
23          responsible for the mass transport of burning embers or firebrands. These are now

---

<sup>18</sup> Malamud, B. D., G. Morein, and D. L. Turcotte (1998), Forest fires: An example of self-organized critical behavior, *Science*, 281, 1840- 1842

<sup>19</sup> Moritz, Max A., et. al; Wildfires, complexity, and highly optimized tolerance; Proceedings of the National Academy of Sciences of the United States of America; December 13, 2005; vol. 102; 17913

<sup>20</sup> Appendix C – Wind and Large Wildland Fires

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 15 of 67**

1 widely acknowledged to be a primary cause of structure ignition. The literature  
2 backing this assertion is reviewed in Appendix C, section 2.3<sup>21</sup>. Briefly, small bits  
3 of burning vegetation are driven by wind into nooks and crannies in the structure,  
4 or ignite flammable materials next to the structure, even if there is separation  
5 between the structure and primary fuels. Eaves, window sills, attic vents, and  
6 under roof tiles have all been observed to be ignition points<sup>22,23,24,25</sup>. Once the  
7 structure ignites, it is very likely to burn down unless the fire is immediately  
8 suppressed, leading to economic loss.

9

10 **Q. Is there a relationship between the largest fires observed in California**  
11 **and strong, dry winds?**

12 **A.** Yes. All of the historically largest fires in terms of structure loss and  
13 economic damage were wind-driven catastrophic wildfires. Halsey<sup>26</sup> has prepared  
14 a table of the thirteen largest fires in California in terms of structure loss and area  
15 burned. Every one of them occurred under conditions of strong dry winds.

16

17 **Q. How do catastrophic wind-driven fires affect public health and**  
18 **safety?**

---

<sup>21</sup> Appendix C – Sec. 2.3

<sup>22</sup> Ramsay, G.C., McArthur, N.A. & Dowling, V.P.; Preliminary results from an examination of house survival in the 16 February 1983 bushfires in Australia. *Fire and Materials*, 11 (1987) 49

<sup>23</sup> FOOTE, E.I.D.; 1994; Structure survival on the 1990 Santa Barbara “Paint” fire: A retrospective study of urban-wildland interface fire hazard mitigation factors. MS thesis, University of California at Berkeley

<sup>24</sup> Cohen, Jack D. 2000. Preventing disaster: home ignitability in the wildland-urban interface. *Journal of Forestry* 98(3): 15-21

<sup>25</sup> Mitchell, Joseph W. and Oren Patashnik; Firebrand Protection as the Key Design Element for Structure Survival during Catastrophic Wildland Fires; *Fire and Materials* 2007, San Francisco, Jan. 2007. Available at: [http://www.mbartek.com/FM07\\_FirebrandsWildfires\\_1.1F.pdf](http://www.mbartek.com/FM07_FirebrandsWildfires_1.1F.pdf)

<sup>26</sup> Halsey, Richard W; *Fire, Chaparral, and Survival in Southern California*; Sunbelt Publications; San Diego; 2005, p. 49

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1           **A.**     The vast majority of deaths and injuries that occur from wildland fire  
2 occur in catastrophic wind-driven fires<sup>27</sup>. The rapid movement and expansion of  
3 the fire front in combination with the large number of homes simultaneously  
4 threatened results in short evacuation notice or none at all. Dense smoke carried  
5 ahead of the front reduces visibility and causes accidents, while restricted egress  
6 from rural neighborhoods slows traffic. Most deaths and injuries occur during  
7 evacuation<sup>28</sup>.

8

9           **6. POWER LINE FIRES**

10

11           **Q.**     **How many of California’s largest and most destructive fires were**  
12 **caused by power lines?**

13           **A.**     This question is analyzed in Appendix D<sup>29</sup>. In this, we review data  
14 available from the CDF in which they tally the 20 largest and the 20 most  
15 destructive fires in recorded California history. This tally shows that three out of  
16 the twenty largest wildland fires were caused by power lines:

17

18

19

20

21	#	Name	Date	County	Acres	Structures	Deaths
22	3	LAGUNA	Sept. 1970	SAN DIEGO	175,425	382	5
23	8	CAMPBELL CPX.	Aug. 1990	TEHAMA	125,892	27	0
24	12	CLAMPITT	Sept. 1970	LOS ANGELES	105,212	86	4

25

---

<sup>27</sup> Ibid.

<sup>28</sup> Webster, Joan; The complete bushfire safety handbook; Random House, Sydney; 2000; p. 214

<sup>29</sup> Attached as MGRA\_Mbar\_SPL\_AppD\_Power lineFires.pdf; Appendix D, Sec. 2.1

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1           Likewise, three of out of the twenty fires causing the greatest loss of structures  
2           were due to power line fires:

3

4	#	Name	Date	County	Acres	Structures	Deaths
5	7	BERKELEY	Sept. 1923	ALAMEDA	130	584	0
6	10	LAGUNA	Sept. 1970	SAN DIEGO	175,425	382	5
7	15	SYCAMORE	July 1977	SANTA BARB	805	234	0

8

9           Data source references can be found in Appendix D<sup>30</sup>.

10

11           **Q.     What fraction of all fires in California is started by power lines?**

12           **A.**Between 2000 and 2005, the CDF reports that roughly 3% of all fires were  
13           started by power lines. Data reference can be found in Appendix D<sup>31</sup>.

14

15           **Q.     What is the probability that the observation of three events out of**  
16           **twenty (15%) is a random fluctuation of the 3% expected fire rate due to**  
17           **power lines?**

18           **A.**This is calculated in Appendix D<sup>32</sup>. The probability that the observed  
19           number of largest fires would randomly end up with three being caused by power  
20           lines is 2%. This is likewise true for the three power line fires in the group of  
21           twenty largest home losses.

22

23           **Q.     What does the discrepancy between the expected number of power**  
24           **line fires in the list of largest and most destructive fires and the expected rate**  
25           **imply?**

---

<sup>30</sup> Appendix D, Section 1

<sup>31</sup> Appendix D, Section 1.2

<sup>32</sup> Appendix D, Section 2.1

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 18 of 67**

1           **A.**     One likely explanation is that there is a common element that causes  
2 power line fires and also causes fires to be larger. As shown in previous sections,  
3 this element is asserted to be wind.  
4

5           **Q.**     **What is the fraction of wildland fires due to power line incidents in**  
6 **San Diego County?**

7           **A.**     This analysis is shown in Appendix D<sup>33</sup>. The CDF offers fire perimeter  
8 data for fires between 1910 and 2005 as GIS data available for download. Only  
9 data on fires greater than 50 acres or responsible for damage is included. Data  
10 associated with these perimeters, such as their date and cause, are also collected.  
11 These data were extracted into a spreadsheet so that statistics could be performed  
12 on them.

13 Total number of fires in the sample is 1,354. Of these, only seven were listed as  
14 power line fires, corresponding to 0.5%. Restricting the sample to after 1960, as  
15 the development of San Diego commenced, reduces the total number of fires to  
16 759. All of the power line fires occurred in the post-1960 time frame, leading to a  
17 rate of 0.9%.

18  
19           **Q.**     **Why would there be fewer power line fires in San Diego County?**

20           **A.**     A likely reason that the rate of power line fires in San Diego County  
21 would be less than that elsewhere in California is the predominance of chaparral  
22 fuel types. Most power line fires are due to tree-power line contact, which is not  
23 as serious of an issue in San Diego due to the comparative scarcity of trees.  
24

25           **Q.**     **How damaging were power line fires in San Diego?**

---

<sup>33</sup> Appendix D, Sec. 2.2 - Power line fires in San Diego, 1910-2005

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1           **A.**     Power line fires in San Diego County have been extremely damaging,  
2 burning a total of 17% of the area burned since 1960.

3           The power line fires are listed below:

4

5	YEAR	FIRE	ACRES
6	1970	LAGUNA	174158
7	1993	GUEJIUTO	17819
8	1997	LAUREL	702
9	1996	PALA	467
10	1999	STEWARD (MAIN)	33.4
11	2002	PINES	61690
12	2005	MILLER	19.7

13

14           The perimeters of these fires are shown in Figure D-3<sup>34</sup>.

15           Both average and median fire sizes were calculated for both power line fires and  
16 for the full post-1960 data set. These and their ratios are shown below:

17

	<b>Fires since 1960</b>	<b>Power line Fires</b>	<b>Ratio</b>
Number of fires	759	7	.0092
Acres burned	1,460,000	255,112	.17
Average fire size	1,924	36,445	19
Median fire size	149	711	4.8

18

---

<sup>34</sup> Appendix D, p. 9

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 20 of 67**

1 Examination of historical data reveals that while power line-related fires have  
2 been fairly rare in San Diego County, constituting less than one percent of all fires,  
3 they have been extremely destructive, burning 17% of all the area burned during  
4 this period. This supports the hypothesis that the increased likelihood of power  
5 line faults during wind events will make it more likely that power line fires are  
6 large, wind-driven fires. Average fire sizes for power line fires have been around  
7 20 times larger than for all fires, while the median fire size has been roughly five  
8 times as large, with the discrepancy caused by the fact that fire statistics tend to be  
9 driven by the largest catastrophic events.

10

11 **Q. What factors might lead to greater or lesser risk of wildland fires than**  
12 **would be indicated in the preceding analysis?**

13 **A.** Historical data will be based upon fewer power lines in operation. This  
14 factor would suggest that the real risk values are HIGHER than those indicated  
15 above.

16 The fact that the proposed route passes through flammable vegetation for a  
17 considerable portion of its path would INCREASE risk.

18 The fact that SPL traverses particularly windy areas of the County would  
19 INCREASE risk.

20 Current population growth trends that INCREASE the number of power lines and  
21 possible impacts of climate change will be effects that will tend to INCREASE  
22 this risk and therefore the number of future power line fires.

23

24 **7. FUEL LOAD HAZARD ALONG THE SUNRISE POWERLINK ROUTE**

25

26 **Q.** What means are available to characterize the vegetation along the SPL  
27 route, and which were chosen?

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE**

**A.06-08-010**

**Page 21 of 67**

1           A.     This analysis is performed in Appendix E<sup>35</sup>. Three means of determining  
2     wildland fire threat from fuels were used. Two of these were based upon fuel  
3     hazard metrics available from CDF through their FRAP service. Another was a  
4     vegetation model (Scott-Burgan) available from the USGS/USFS/BLM  
5     LANDFIRE project. These reference data are described in Appendix E<sup>36</sup>.  
6     Two allow a quantitative analysis of the SPL route, it was divided into 1 km  
7     segments and the vegetation type and hazard along each segment was calculated.  
8     This type of route hazard analysis is extremely useful, because it allows the  
9     correlation in space of various hazard factors that affect each other for fire risk  
10    estimates (for instance, wind and vegetation). Data in the EIR should be provided  
11   to the public in this format, since it does not require GIS software for  
12   manipulation. For comparison, the route of the Southwest Powerlink (SWPL) is  
13    also analyzed, since part of the justification used for an alternative route for SPL  
14    by SDG&E is that the existing SWPL is excessively fire-prone. This file has been  
15    attached to Appendix E as Route\_Analysis\_SPL\_1.1.xls<sup>37</sup>. An example of this  
16    type of analysis can be seen in Figure E-1<sup>38</sup>. One note to emphasize is that  
17    vegetation types and fuel exposures are very mixed on the scale of 1 km, so the  
18    algorithm used to select a ranking is consisted of choosing the most hazardous  
19    fuel, threat, or vegetation ranking with significant line exposure (more than about  
20    10% of the kilometer span).  
21    Fuel Rank was one of the datasets supplied by CDF, and it takes into account both  
22    the vegetation type and the slope to calculate the relative intensity of a fire using  
23    the following scale: -1 = Non-Fuel, 1 = Moderate, 2 = High, 3 = Very High. This  
24    scale projected onto San Diego County and showing the proposed SPL and the

---

<sup>35</sup> Attached as MGRA\_Mbar\_SPL\_AppE\_Vegetation.pdf

<sup>36</sup> Appendix E, Section 1

<sup>37</sup> Attached as RouteAnalysis\_1.1.xls. Original Excel file available upon request from MGRA.

<sup>38</sup> Appendix E, p. 7



**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1 SWPL routes is shown in Figure E-2<sup>39</sup>. One problem with the CDF Fuel Rank,  
2 aside from the coarse scale, is the fact that it is based on a 2004 survey in the  
3 immediate aftermath of the 2003 fires – Cedar, Paradise, and Otay, and the 2002  
4 Pines fire. This creates a zone of reduced fuel load within the footprints of these  
5 fires, as shown in Figure E-4<sup>40</sup>. While this may be true now, it will be much less  
6 so in the near future as the vegetation regenerates, and this is the time period of  
7 interest for the proposed project. Hence, the CDF Fuel Rank, or any other analysis  
8 using it, is not the best predictor of the fuel load to be expected during the 40 year  
9 lifetime of the project.

10 An alternative is the CDF Fire Threat ranking, which incorporates the Fuel Rank  
11 and then also takes into account the mean fire recurrence time, which CDF has  
12 calculated based on historical fire data. This has the added advantage of taking  
13 ignition sources into account. The scale is as follows:

14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

THREAT	DESCRIPTION
-----	-----
-1	LITTLE OR NO THREAT
1	MODERATE
2	HIGH
3	VERY HIGH
4	EXTREME

---

<sup>39</sup> Appendix E, p. 9

<sup>40</sup> Appendix E, p. 11

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 23 of 67**

1 This metric as applied to San Diego County and the proposed and existing power  
2 line route is shown in Figure E-5<sup>41</sup>.  
3 Finally, vegetation analysis for the LANDFIRE project has just been completed  
4 for California, and all areas have been analyzed according to the Scott & Burgan<sup>42</sup>  
5 vegetation model. These vegetation types are classified as to expected fire  
6 behavior. They are shown for San Diego County and the proposed SPL and  
7 existing SWPL route in Figure E-7<sup>43</sup>. As the data is very fine grained, it is  
8 difficult to translate it into a form directly comparable to the other models. To aid  
9 in this, the fuel models were all ranked as to what their expected flame lengths  
10 would be for a 10 mph wind and vegetation with low moisture levels. These flame  
11 lengths are tabulated in Table E-3<sup>44</sup>. A second step was to divide these into four  
12 classes 0 = non-burnable, 1 = low (<5'), 2 = medium (5 ≤ 15') and 3 = high (≥  
13 15'). This allows direct comparison with the other coarse-grained CDF models.  
14

15 **Q. How much of the SPL route is exposed to flammable vegetation, and**  
16 **how does this compare to the existing SWPL route?**

17 **A.** Line distances for SPL proposed and SWPL routes which pass through  
18 each CDF Fuel Rank zone are shown in Figure E-3<sup>45</sup>. The results of these  
19 histograms are tallied below:  
20  
21  
22

---

<sup>41</sup> Appendix E, p. 13

<sup>42</sup> Scott, Joe H.; Burgan, Robert E. 2005. Standard fire behavior fuel models: a comprehensive set for use with Rothermel's surface fire spread model; Gen. Tech. Rep. RMRS-GTR-153; Fort Collins, CO; U.S. Department of Agriculture, Forest Service, Rocky Mountain Research Station

<sup>43</sup> Appendix E, p. 16

<sup>44</sup> Appendix E, p. 17

<sup>45</sup> Appendix E, p. 10

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

<b>CDF Fuel Rank</b>	<b>SPL Proposed (km)</b>	<b>SWPL (km)</b>
Fuel rank $\geq 1$ (moderate)	234	133
Fuel rank $\geq 2$ (high)	116	95
Fuel rank =3 (very high)	27	34

1           The distance which the proposed SPL and existing SWPL routes traverse each  
2           Fire Threat zone are shown in histograms in Figure E-6<sup>46</sup>, respectively.    These  
3           results are summarized in the table below:

4

<b>CDF Fire Threat Rank</b>	<b>SPL Proposed (km)</b>	<b>SWPL (km)</b>
Fire Threat $\geq 1$ (moderate)	234	132
Fire Threat $\geq 2$ (high)	109	95
Fire Threat $\geq 3$ (very high)	68	88
Fire Threat = 4 (extreme)	20	14

5

6           The distance which the proposed SPL and SWPL routes traverse the reduced  
7           Scott-Burgan vegetation regimes is shown in the histograms in Figure E-8<sup>47</sup>.

8           These results are summarized in the table below:

9

---

<sup>46</sup> Appendix E, p. 14

<sup>47</sup> Appendix E, p. 18

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

<b>Scott-Burgan Vegetation</b>	<b>SPL Proposed (km)</b>	<b>SWPL (km)</b>
SB Veg. Class $\geq 1$ (0-5')	147	107
SB Veg. Class $\geq 2$ (5-15')	137	83
SB Veg. Class = 3 (>15')	43	45

1

2           Comparison of the proposed SPL route and the SWPL line and their respective  
3 exposure to ignition-prone vegetation once again displays that the SPL route has a  
4 considerably longer exposure (50-60%) to moderately to highly flammable  
5 vegetation than the existing SWPL route. In its proposal for this route, SDG&E  
6 uses the fire-prone condition of the SWPL corridor as motivation for selecting  
7 another route for SPL. What this analysis shows is that the preferred SPL corridor  
8 may be expected to have an equivalent or greater exposure to fire danger due to  
9 its longer path length, much of which spans flammable vegetation.

10           The three metrics examined – CDF Fuel Rank, CDF Fire Threat, and Scott-  
11 Burgan Vegetation, all indicate that the SPL route traverses a longer path (150-  
12 240 km, 50-100% more than SWPL) of significant fire risk than SWPL, while  
13 they are roughly equivalent in the 20-40 km span of extremely hazardous area that  
14 they span. The exposure to wildfire faced by San Diego County will be increased  
15 by the degree to which these lines present an ignition source. From this  
16 standpoint, we can conclude that the proposed SPL route presents a greater risk of  
17 starting a wildland fire than does the existing SWPL route.

18

19           **Q.     How do the line exposures of the proposed SPL route and SWPL**  
20 **compare to those of the rest of the SDG&E transmission network?**

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1           **A.**     It is not possible to calculate this value because SDG&E has refused to  
2 supply data on the remainder of its transmission network, citing security  
3 concerns<sup>48</sup>. The applicant should be directed to conduct a comparison of the  
4 vegetation and fuel exposure of its proposed route with that of the rest of its  
5 transmission network so that outage and fire rates can be appropriately scaled  
6 from the existing network. This work should be conducted as part of the EIR.

7

8           **8. WIND EXPOSURE OF POTENTIAL SPL ROUTES**

9

10           **Q.**     **Are locations in San Diego County equally vulnerable to Santa Ana**  
11 **wind events?**

12           **A.**     No. Analysis of data from RAWs weather stations going back to 2002  
13 reveals that some locations in San Diego County experience Santa Ana wind  
14 conditions more strongly than others<sup>49</sup>. Some areas experience stronger winds,  
15 while some are more likely to exhibit low humidity conditions. Results are  
16 summarized in the table below, for number of hours per year that wind speeds  
17 greater than 30 miles per hour are experienced:

18

<b>RAWs Weather Station</b>	<b>2006</b>	<b>2005</b>	<b>2004</b>	<b>2003</b>	<b>2002</b>
<b>Potrero</b>	164/164	76/31	89/46	--	--
<b>Goose Valley</b>	14/14	5/2	5/5	48/41	32/27

---

<sup>48</sup> SDG&E responses to data requests MGRA-3, MGRA-4, and MGRA-39.

<sup>49</sup> Appendix F, Section F2.1

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

<b>Julian</b>	290/65	65/0	--	--	--
<b>Ranchita</b>	411/12	476/6	522/26	686/31	514/61

1           The Goose Valley weather station is to the north-east of Ramona. The numbers to  
2           the left side of the forward slash are the total number of hours measured with gust  
3           speeds in excess of 30 mph, while the right side matches the same condition with  
4           the additional requirement that humidity be less than 20%, thus characterizing  
5           “Santa Ana” wind conditions.

6

7           **Q.     What fractions of time do given locations spend under “Santa Ana”**  
8           **conditions?**

9           **A.**In order to determine these numbers, the values in the above table are  
10          divided by the number of “live” hours for each weather station. Doing so  
11          produces the following result:

12

	<b>2006</b>	<b>2005</b>	<b>2004</b>	<b>2003</b>	<b>2002</b>
<b>Potrero</b>	0.0194	0.00368	0.00559	--	--
<b>Goose Valley</b>	0.00204	0.000291	0.000589	0.00491	.00321
<b>Julian</b>	0.00769	0.0	--	--	--
<b>Ranchita</b>	.00141	0.000716	0.00305	0.00366	0.00791

13

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 28 of 67**

1 Hence, over all years and stations, the fraction of time spent under “Santa Ana”  
2 conditions can vary from .05 - .8%, making these uncommon events from a  
3 statistical standpoint.

4

5 **Q. Why is the weather station data incomplete?**

6 **A.** Because this data had to be extracted manually, there was insufficient time  
7 to extract all relevant data. Santa Ana wind data for all weather stations relevant  
8 to proposed routes should be extracted and entered as part of the EIR.

9

10 **Q. How can the values in the table above be related to proposed SPL**  
11 **route?**

12 **A.** The Julian and Ranchita stations are particularly close to the proposed  
13 SPL route. However further interpolation between these stations can be done  
14 using computer modeling. Computer models, in the form of digital forecasts for  
15 the immediate future, are available from the National Weather Service, and have  
16 been available to the public since 2006.

17 This method has been evaluated in Appendix F<sup>50</sup>, by comparing RAWS weather  
18 station data with the digital forecast and was found to be applicable. Some  
19 stations, such as Julian, Potrero, and Ammo Dump, were found to have weather  
20 data that was correlated, albeit broadly, with the predicted values from the digital  
21 forecast. Other stations, such as Goose Valley and Ranchita, did not correlate  
22 well, either because the model was inaccurate in their locales or because the  
23 specific station locations were not typical of the 5 km grid element in which the  
24 model placed them.

25 In order to characterize any SPL proposed route, the following should be  
26 undertaken in the EIR:

---

<sup>50</sup> Appendix F, Sec. 2.2

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 29 of 67**

- 1           1) More computer data from Santa Ana events should be collected using  
2           the method specified in Appendix F<sup>51</sup>.  
3           2) These data, in map format (such as Figure F-2<sup>52</sup>) should have their  
4           maximum values averaged to create an “average” Santa Ana threat map.  
5           3) The wind values should be added to the Route Hazard Analysis grid, so  
6           that they can be correlated with vegetation.  
7

8           **Q.     What are the characteristics of typical wind distributions during a**  
9           **Santa Ana wind event?**

10          **A.**     During a typical Santa Ana wind event, an example of which is shown in  
11          Figure F-2, there is a band of high winds stretching from north to south through  
12          the center of San Diego County, with the highest winds in the central  
13          mountainous regions. Within this band there are two concentrations of  
14          exceptionally high winds, one of which occurs near Julian in the north and the  
15          other near Potrero and Campo in the south. These affect both the SPL proposed  
16          route and the SWPL route.  
17

18          **9. EFFECT OF SANTA ANA WINDS ON SUCCESS OF FIRE SUPPRESSION**  
19

20          **Q.     What is the success rate of fire service initial attack in controlling fires**  
21          **before they become major fires?**

22          **A.**     Data from the CDF (now Calfire) ignition database was obtained<sup>53</sup>. Data  
23          records for 941 fires between 2003 and 2006 were analyzed. It was found that  
24          97.8% of fires were controlled before they reached 100 acres in size, while 91.5%  
25          of fires were controlled before they reached 10 acres in size.

---

<sup>51</sup> Attached as MGRA\_Mbar\_SPL\_AppF\_SAWind.pdf

<sup>52</sup> Appendix F, p. 10

<sup>53</sup> Section F2.3



**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 30 of 67**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**Q. How do Santa Ana wind conditions affect the probability of successful fire service initial attack?**

**A.** By comparing the ignition data with weather station data, it has been shown that all major fires larger than 100 acres occurred when the nearest weather station measured gusts of 30 mph or more. Fourteen fires were ignited under these conditions. Of these, 5 events were larger than 100 acres and 6 events were larger than 10 acres, corresponding to approximate attack success rates of 64% and 57%, respectively.

**Q. What is the expected occurrence rate, based on the estimates made on page 6, of a large fire from SPL that escapes initial attack by firefighters?**

**A.** The rate was estimated at one per 15-20 years (4 year – 200 year 90% confidence level) for the occurrence of a fire. Assuming that a fire would start when wind gusts speeds are in excess of 30 mph, the predicted large fire rate would be one every 42 to 56 years. The uncertainty range would be relatively broader because of the uncertainty in regard to the initial attack success rate.

**Q. Are there other methods that can be used to obtain estimates of fire rates?**

**A.** Yes, there are other methods which can be used for this estimation. Five of these are listed in Appendix F, Section 2.5, and others may be devised. Assuming that all transmission lines have equal fire rates would yield a recurrence rate of 79 years (40% probability of a significant fire in 40 years). Prediction using CDF fire histories going back longer in time, but having no transmission line history, yields a recurrence rate of 217 years if ad-hoc assumptions are made about the growth of the transmission network. These same assumptions lead to a lower limit on the recurrence time due to the fact that no significant historical

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 31 of 67**

1 transmission line fires have been observed. Asserting that the fault rate ratios  
2 between 69 kV and 230 kV lines are indicative of fire start rates leads to a  
3 reduction in the predicted rate by a factor of 2.8, giving a recurrence rate of 220  
4 years (18% probability of a significant fire in 40 years).

5

6 **Q. What is the preferred method for calculation?**

7 **A.** The preferred method of calculations uses the fewest unproven  
8 assumptions to calculate the predicted fire recurrence times. Basic assumptions  
9 inform all predicted fire rates, as shown in Appendix F, Table F-3<sup>54</sup>, however  
10 some of these assumptions are more ad-hoc than others. In particular, the growth  
11 of the transmission and distribution networks over time is critical to using  
12 historical data, and this should be included in the EIR. Another ad-hoc assumption  
13 would be to assume that fire starts scale with fault rates, since the higher energy  
14 of faults on higher voltage lines could lead to a greater fire start rate. The simplest  
15 calculation remains to take the well-measured recent data as indicative of future  
16 fire rates, and this remains the preferred calculation. If the data on the historical  
17 growth of distribution and transmission lines is obtained, this should be used to  
18 recalculate likelihoods combining the historical and recent data sets. This should  
19 be done in the EIR.

20 Therefore, I recommend that the primary calculation be used as the basis for  
21 future prediction until such data is obtained and analysis done. The validity of all  
22 assumptions should be examined within the scope of the EIR, in order to choose  
23 the best and most predictive model.

24 **Q. What is the significance of the various calculations, their similarities**  
25 **and differences?**

26 Despite the broad range of obtained values, they are not outside of the range of

---

<sup>54</sup> Appendix F, p. 25

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 32 of 67**

1 variation stated for the original calculation. The initial assumptions chosen to  
2 perform the primary risk calculations in Appendix B and in section 2.4 of this  
3 appendix were those that used known data, made the fewest assumptions and used  
4 the simplest models.

5 *All these predictive analyses assume that SPL would be no more or less likely to*  
6 *start a fire than other line in the network. However, much of the work in the*  
7 *accompanying appendices indicates that it is unusually exposed to conditions*  
8 *that create a fire hazard.*

9 Notably, ALL of these methods (aside from the limit in Appendix F, section  
10 2.5.4.3) imply that there is a significant foreseeable risk of wildland fire being  
11 caused by the Sunrise Powerlink during its estimated lifetime, even when ignoring  
12 the particular but very significant hazards of the proposed route and alternatives.  
13 Hence, it follows that economic impacts of such fires need to be calculated.

14

15 **10. LIABILITY DUE TO LOSSES FROM POWER LINE FIRES**

16

17 **Q. Might SDG&E be held liable for damages caused by fires started by**  
18 **power lines or other equipment?**

19 **A.** Yes. Appendix G<sup>55</sup> lists statute and case law that may be relevant to power  
20 line fire cases. Among the statutes are:

21

22 CACI 416

23 “AMOUNT OF CAUTION REQUIRED IN TRANSMITTING ELECTRIC

24 POWER

---

<sup>55</sup> Attached as MGRA\_Mbar\_SPL\_AppG\_Liability.pdf

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 33 of 67**

1 People and companies must be very careful in constructing, insulating, inspecting,  
2 maintaining, and repairing power lines and transmission equipment at all places  
3 where it is reasonably probable that they will cause harm to persons or property.”  
4

5 Cal Health & Safety Code § 13007

6 “Any person who personally or through another willfully, negligently or in  
7 violation of law, set fire to, allows fire to be set to, or allows a fire kindled or  
8 attended by him to escape to, the property of another, whether privately or  
9 publicly owned, is liable to the owner of such property for any damages to the  
10 property caused by the fire.”

11 The following cases have been found to be relevant in power line fire cases:  
12

13 Lozano v. PG&E Co., 70 CA.2d 415(1945)

14 “The duty of due care with which the company was charged consists not only in  
15 the proper installation of the dangerous instrumentality but in the maintenance  
16 thereof in a safe condition at all times and places and under the changing  
17 circumstances of the particular case. Even if at the outset of the installation of the  
18 equipment the company may have been entirely free from fault, yet, if under  
19 changing circumstances, a hazardous condition arose, nonaction or the failure to  
20 remedy such condition would constitute culpable negligence. (Cites)” (P.423)”  
21

22 Ireland-Yuba Gold Quartz Mining Co., v. PG&E, (1941) 18 C.2d 557.

23 “It is not unreasonable to require Appellant to anticipate that with high winds  
24 usually blowing in the vicinity in which the fire occurred, the tree might fall  
25 across and break one of the wires. Under the circumstances here presented,  
26 Appellant was bound to anticipate the existence of a wind even of high velocity  
27 where such winds were not unusual. (Cite)”. (P.565). – This indicates duty to  
28 consider wind conditions.

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 34 of 67**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27

Beresford v. PG&E (1955) 45 C.2d 738

“ . . . if, under changing circumstances, a hazardous condition arose, nonaction or the failure to remedy such condition would constitute culpable negligence.

(Cite).” (P.746)”

“ . . . not unreasonable to require the power company to anticipate that during a high wind a tree might fall across high voltage lines and result in a fire.”

**Q. Can additional damages be levied against SDG&E above and beyond those caused by a fire?**

**A.** Yes. Two theories supporting additional damages have been used in power line fire cases. The first is the theory of trespass, which allows the assessment of double or triple damages to the plaintiff, as well as the awarding of attorney fees. The theory of trespass in regard to fire is supported by the following case:

Elton v. Anheuser Busch etc. (1996) 50 CA.4th 1301

“It would be difficult to justify a distinction between damage caused by the thermal energy of a fire and that caused by the kinetic energy of vibrations. Certainly, a fire presents a potential for damage and destruction which is at least as great as that presented by vibrations. When negligently inflicted with resulting actual damage, either way constitute a trespass. Since it is undisputed that the fire in this instance cause actual damage to the Plaintiff’s property and since the jury expressly found that those damages were caused by the Defendant’s negligence, the invasion of the fire onto Plaintiff’s property constituted a trespass.” (P.1307)

Another theory that can be used to support double or triple damage assessment is the theory of inverse condemnation, which is used in the event that private property is condemned by a public agency without due process. Because of their

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 35 of 67**

1 power of condemnation, utilities have been held to be public agencies in regard to  
2 their liability. This is supported by the following case:

3

4 Barham v. So. Cal. Edison, (1999) 74 CA.4th 744

5 “. . . SCE may be liable in inverse condemnation as a public entity. Further, Art.  
6 1 § 19 of the California Constitution and the cases which interpret and apply it  
7 have as their principal focus the concept of public use, as opposed to the nature of  
8 the entity appropriating the property.” (P.753)

9 “Rather, the issue is whether the Barham’s property was taken for a public use,  
10 i.e., the transmission of the electric power to the public. The evidence reflects the  
11 circuit of which the subject pole and transmission wires were a part, provides  
12 electric service to more than 1000 households. Based upon the above cited  
13 authority, we must conclude that the transmission of electric power through the  
14 facilities (i.e. broken electric line) that caused damage to the Barham’s property  
15 was for the benefit of the public . . . Thus the Barham’s property was ‘taken or  
16 damaged’ for a public use.” (P.754)

17 It has also been held in the following case that public agencies may also invoke  
18 inverse condemnation against other public agencies:

19 Marin Mun. Water Dist. v. City of Mill Valley (1988) 202 Cal App 3rd 1161.

20

21 **Q. Can these damages be passed on to SDG&E ratepayers?**

22 **A.** Yes, partially or fully.

23 In one regard, since the proposed SPL route runs through the SDG&E service  
24 area, it is likely that property damage accrued by any fire started as a result of the  
25 SPL will be incurred by SDG&E customers, regardless of whether SDG&E is  
26 held liable for the fire. Hence, damages should be incorporated into rate payer  
27 benefit calculations.

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 36 of 67**

1           In the case that SDG&E is found liable, according to its reply to data request  
2           MGRA-28, it may pass on some costs:  
3           “SDG&E maintains a significant self-insured retention for third party liability  
4           insurance. Disaster costs within the self-insured retention are paid for by  
5           transmission customers. Commercial insurance for third party liability arising out  
6           of disasters and/or emergencies is purchased above the self-insured retention.”  
7           Hence, ratepayers will need to refresh the self-insured retention. They also help  
8           pay the premiums for the commercial third party liability insurance. In the event  
9           of a major fire event due to either SDG&E negligence *or that of another insured*  
10          *utility*, insurance rates may be substantially increased, or insurance on the current  
11          terms might no longer be available. It is probable that these added costs would be  
12          passed on to consumers through higher utility prices. SDG&E should disclose  
13          these costs, and they should be explicitly included in the cost/benefit calculation  
14          for the proposed line.

15

16       **11. ECONOMIC IMPACTS OF WILDLAND FIRE – PROPERTY DAMAGE**

17

18           **Q.     What is the most economically significant damage that is likely to be**  
19           **caused by power line fires?**

20           **A.     The most significant damage likely to be caused by power line fires is**  
21           property damage. Data from the Insurance Information Institute for the sixteen  
22           most damaging wildland fires in the United States since 1970 are tabulated in  
23           Appendix H<sup>56</sup>. These sixteen fires were responsible for \$ 7 billion in property  
24           damage.

25

26           **Q.     What were the largest fires in terms of losses?**

---

<sup>56</sup> Attached as MGRA\_Mbar\_SPL\_AppH\_Costs.pdf; Appendix H, section H2.1

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 37 of 67**

1           **A.**     The largest fires in terms of losses were the Oakland or “Tunnel” fire of  
2           1991, which was responsible for \$2.5 billion in 2006 dollars, and the Cedar fire of  
3           San Diego County, which was responsible for \$1.2 billion in 2006 dollars.  
4           Together these two fires were responsible for \$3.7 billion dollars of loss, which is  
5           over half of the losses in the table.

6

7           **Q.**     **How do the rest of the fires in the list contribute to overall loss?**

8           **A.**     Every pair of adjacent fires in the list have losses that when summed  
9           exceed the sum of losses of the rest of the files lower down the list. In other  
10          words, big fires dominate no matter what scale is chosen.

11

12          **Q.**     **Is there a reason for this steep fall in loss sizes as we go down the list?**

13          **A.**     Probably. It is likely due to the fact that wildland fire sizes are well  
14          described by the models arising out of complexity theory, which were described  
15          in Appendix C<sup>57</sup>. These lead to size relationships described by “power-law”  
16          functions that often display this type of behavior. Since economic losses will to  
17          some degree be affected by fire size, we might expect this type of relationship to  
18          apply to losses as well as fire area.

19

20          **Q.**     **What would a power-law relationship in wildland fire loss sizes imply  
21          for how potential economic losses from wildland fires should be calculated?**

22          **A.**     It would mean that the most extreme events, though very rare, must be  
23          factored into the economic analysis of wildland fire because their costs rise more  
24          steeply than their probability falls.

25

26          **Q.**     **What is the maximum loss size that should be considered?**

---

<sup>57</sup> Appendix C, section C2.2



**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 38 of 67**

1           **A.**     There is usually a cut-off value for maximum loss for this type of  
2 behavior, which depends on system size, but it is not clear whether this has yet  
3 been reached. In the Cedar fire for instance, only a sudden change in wind  
4 direction, accompanied by extreme firefighting effort, prevented the head of the  
5 fire from following the coastal canyons into the high-value community of La  
6 Jolla, which if it had happened would have further multiplied losses.

7

8           **Q.**     **How should these low probabilities and costs be taken into account**  
9 **when doing an economic analysis?**

10          **A.**     One way to address these costs as applied to the SPL is to calculate the  
11 ‘minimum’ insurance premium that would effectively cover these damages. This  
12 can be determined by multiplying the probability of the catastrophic event by its  
13 cost, and then amortizing over the lifetime of the project.

14

15          **Q.**     **What is the probability of catastrophic losses near the upper end of**  
16 **the loss scale?**

17          **A.**     If we look at Figure F-4<sup>58</sup>, this shows only a few points for fires started  
18 during periods of high winds that are not rapidly controlled. What is noteworthy,  
19 though, is that these few points seem to be distributed in a “flat” manner  
20 logarithmically. In other words, medium-sized fires show up as often as large  
21 fires, which show up as often as huge fires. Keep in mind that the 2003 firestorm  
22 dominates this graph, and this being such an extreme event might not be  
23 representative of future catastrophic fires (but then again, it might). We can  
24 therefore calculate a “pessimistic” case, which is suggested by the graph, and an  
25 “optimistic” case, which uses a value five times less for the probability than the  
26 pessimistic case.

---

<sup>58</sup> Appendix F, p. 15

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1           The mean time between fires escaping initial attack for the proposed SPL has  
2           already been very roughly estimated to be 42 years. We have chosen the  
3           optimistic case and the pessimistic case accordingly to be 10% and 2% probability  
4           over the 40 year lifetime of the line.

5

6   **12. COST/BENEFIT IMPACTS FROM PROPERTY DAMAGE**

7

8           **Q.     What damages are used for this calculation?**

9           **A.**We assume a maximum value of \$1 billion dollars as the raw economic  
10          damages that would accrue as a worst-case catastrophic fire entering the  
11          developed portions of San Diego County. This may be a conservative figure,  
12          because some “reasonable” fire paths could impact even more properties than the  
13          Cedar fire. However, as fire sizes approach their maximum size, departures from  
14          power-law behavior are expected, with lower probabilities.

15          Additionally, SDG&E might be held liable for double or triple damages under the  
16          theories of trespass or inverse condemnation, as described in Appendix G<sup>59</sup>. This  
17          is also factored into the calculation.

18

19          **Q.     What is the probability-weighted cost due to catastrophic fire that we  
20          can expect for the SPL?**

21          **A.**This is shown in the table below:

22

<b>Damages</b>	<b>Probability</b>	<b>Cost/yr</b>	<b>Liability</b>	<b>Cost/yr</b>
\$1,000 M	10%	\$ 2.5 M	\$ 3,000 M	\$ 7.5 M
\$1,000 M	2%	\$ 0.5 M	\$3,000 M	\$ 1.5 M

23

---

<sup>59</sup> Appendix G, section G2.1

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 40 of 67**

1 The cost per year shown in the table is the “minimum insurance premium” that  
2 SDG&E would need to pay to cover the cost of a \$1 billion catastrophic fire. This  
3 is calculated for the 2% and 10% probability cases, and also for the case of triple  
4 damage awarded. This value ranges from \$0.5 to 7.5 million per year.

5 Note that this is simply illustrative of the method that should be used to estimate  
6 cost/benefit impacts of the SPL, and a full estimate using proper actuarial  
7 techniques should be performed in the EIR.

8

9 **Q. How should this cost per year derived from the probability-weighted**  
10 **cost be applied to the cost/benefit analysis for the proposed SPL?**

11 **A.** The yearly cost of the “insurance premium” should be subtracted from the  
12 societal benefits claimed for the line, and then factored into the cost/benefit  
13 analysis. This is justified from the standpoint that if the community of ratepayers  
14 would benefit from the SPL economically due to lower rates, they would also  
15 have to bear the brunt of any damages caused by fire – either directly, or through  
16 higher rates due to losses by SDG&E or higher insurance premiums being levied  
17 upon SDG&E.

18

19 **Q. What are the uncertainties in the above calculation?**

20 **A.** As previously stated, uncertainty in the 42 year recurrence rate is greater  
21 than a factor of ten. *However, it also assumes that the SPL is no more or less*  
22 *likely to cause fire than other transmission lines. Other portions of this*  
23 *testimony indicate why the risk along the proposed SPL route may be higher*  
24 *than that expected for other transmission lines.*

25 Other uncertainties include the fact that as population grows in San Diego, the  
26 number of high-value properties along the wildland-urban interface will increase,  
27 thus increasing the maximum potential fire loss. Additionally, climate change  
28 could make the fire season longer and more severe. However, future advances in

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 41 of 67**

1 construction techniques, technologies, or fire fighting capabilities might reduce  
2 losses.

3

4 **13. COST/BENEFIT IMPACTS OF HABITAT RESTORATION OR**  
5 **REPLACEMENT**

6

7 **Q. Are there other economic damages that might accrue from a power**  
8 **line fire started by the SPL?**

9 **A.** Yes. There is the possibility that habitat could be permanently lost or put  
10 at risk, and that SDG&E would be required to correct this loss.

11

12 **Q. How can San Diego habitat be put at risk by wildland fire?**

13 **A.** The chaparral of Southern California is fire-adapted. However, if fires are  
14 too frequent, a process called “type conversion” occurs, in which invasive, highly  
15 flammable weeds replace the native chaparral. This is described in Appendix H<sup>60</sup>.  
16 A good review of this phenomenon which cites the major sources is given by  
17 Halsey<sup>61</sup>. Type conversion could have severe ecological impacts and should be  
18 dealt with in depth in the EIR. It could also have economic impacts on ratepayers  
19 if SDG&E were required to replace or restore preserved habitat.

20

21 **Q. What areas along the proposed route are at risk for type conversion?**

22 **A.** Areas in San Diego County which have recently burned will be at risk for  
23 type conversion until their chaparral communities stabilize, a period of about 10  
24 to 20 years. In particular, areas near potential ignition sources such as the SPL or  
25 SWPL will be at greater risk. These areas, along with the age of their

---

<sup>60</sup> Appendix H, Section H2.2

<sup>61</sup> Halsey, p. 25

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1 corresponding fires, are shown in Figure H-2. In particular, significant portions of  
2 the proposed SPL route follow the path of the Cedar fire.

3 The route hazard analysis (attached in Appendix C) also has been used to  
4 calculate the at-risk segments of both the proposed SPL route and the exiting  
5 SWPL route for comparison. Results are shown in the table below:  
6

<b>Date last fire</b>	<b>SPL(km)</b>	<b>SWPL(km)</b>
1991-1995	0	10
1996-2000	0	16
2001-2003	57	24
2004-2005	13	5
<b>Total</b>	70	55

7  
8 Including only line segments with flammable vegetation, 67% of the proposed  
9 SPL route that is at risk of ignition is also at risk for type conversion, as opposed  
10 to 61% for the SWPL route.

11  
12 **Q. How much of the land at risk is in public preserves?**

13 **A.** A very significant percentage of the proposed SPL route is either through  
14 or adjacent to public lands, at least in San Diego County<sup>62</sup>. The total path length  
15 of the proposed SPL route adjacent to or through public lands is 100 km, or  
16 roughly 41% of its total path in San Diego County, as opposed to 35 km for  
17 SWPL. We also calculate the length of these segments west of where the region  
18 of significantly flammable vegetation begins (km 138 for SPL proposed; km 45  
19 for SWPL). These give 62 km for SPL and 35 km for SWPL of path adjacent to

---

<sup>62</sup> Appendix H, Section H2.3

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 43 of 67**

1 public property. This implies that 59% of the SPL path at risk for fire is adjacent  
2 to public lands.

3

4 **Q. What public lands would be affected by the proposed SPL route?**

5 **A.** Public lands affected by the preferred route are owned by the City of San  
6 Diego, the County of San Diego, and the BLM, and include the Mt. Gower Open  
7 Space preserve, the Los Penasquitos Canyon Prserve, the Boulder Oaks Open  
8 Space preserve, the Sycamore Canyon Preserve, Mt. Gower Open Space preserve,  
9 among many others. Alternative routes have similar impacts on these and other  
10 preserves.

11

12 **Q. Are these the only lands that would be at risk in the event of a power**  
13 **line fire?**

14 **A.** No. Public lands will be at risk of exposure to power line wildland fires  
15 even if they are far removed from the ignition source, due to the tendency of  
16 catastrophic wildland fires in San Diego County to spread rapidly westward.

17

18 **Q. How might damages to public lands due to type conversion be**  
19 **remedied by SDG&E?**

20 **A.** These damages could be remedied either by restoring the chaparral  
21 communities using established methods, or by replacing the public preserve with  
22 an equivalent preserve. SDG&E might also be held responsible for double or  
23 triple damages under the theory of inverse condemnation.

24

25 **Q. What are the costs for restoration?**

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1           **A.**     Estimates were received from a consulting firm that does restoration  
2           work<sup>63</sup>, and the costs range from \$42,000 - \$60,000 per acre depending upon the  
3           method chosen.

4

5           **Q.**     **How will the fraction of public lands along the proposed SPL route at**  
6           **risk for type conversion change over time?**

7           **A.**     Due to the adjacency of the proposed SPL route to public lands, the  
8           probability that a fire started by the line will escape onto San Diego County public  
9           lands is over 59%. The fraction of land along the proposed route vulnerable to  
10          both ignition and type conversion for the next 20 years is 67%. Even as the 2003  
11          fire scars heal, new ones will take their place, as indicated in the SWPL fire data,  
12          though we might reasonably expect the total exposed fraction to reduce due to the  
13          historically large nature of the 2003 fires. We shall use 50% as the minimum  
14          fraction for the period after 2025. The EIR should study the average historical  
15          exposure to type conversion by looking at fire history throughout San  
16          DiegoCounty and determining what the probability has been historically that any  
17          given location has had a fire within the last 20 years.

18

19          **Q.**     **What are the costs for restoration that could be anticipated over the**  
20          **lifetime of the line, and how can these be included in the cost/benefit ratio?**

21

22          **A.**     We can apply an actuarial method similar to that used for calculating  
23          potential property damage by calculating the full cost incurred and weighting it by  
24          the probability of fire. Many preserves are on the order of 1,000 acres, and this is  
25          used as a median value for the potential size of public lands that could be at risk

---

<sup>63</sup> Appendix H, Section H2.4

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 45 of 67**

1 in the aftermath of a major fire. We assume a restoration cost of \$50,000 per acre  
2 and a recurrence rate of 42 years.

3

4 For the first 15 years of line operation we get:

5 30% probability \* 1,000 acres \* \$50k/acre \* 59% pub lands  
6 \* 67% type conv \* 3X damages = \$ 21.3 M

7

8 For the period from 2025 to 2050,

9 45% probability \* 1,000 acres \* \$50k/acre \* 59% pub lands  
10 \* 50% type conv \* 3X damages = \$ 19.9 M

11

12 Total for the 40-year life of the line would then be \$40.2 million, which amortized  
13 would be a cost of \$1.0 M/year. This would be the cost of the minimum insurance  
14 premium to safeguard against this contingency.

15 While this represents a 'ceiling' for costs as far as reparations per acre, it does  
16 NOT properly characterize the extent of possible damages if a catastrophic fire  
17 were to damage multiple large preserves. This should be fully analyzed in the  
18 EIR.

19 Note that this is simply illustrative of the method that should be used to estimate  
20 cost/benefit impacts of the SPL, and a full estimate using proper actuarial  
21 techniques should be performed in the EIR.

22

23 **Q. What would be the cost of land replacement, rather than restoration?**

24 **A.** At least presently, the cost of land replacement is significantly less than  
25 that of restoration. Data back to 2001 was scanned for large parcel real estate sold  
26 in San Diego County<sup>64</sup>. Between late 2001 and the present (May, 2007), the

---

<sup>64</sup> Appendix H, Section H2.5



**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

1 average price per acre for large (300+) parcels has been \$2565.11. The purchases  
2 of preserves under San Diego County's Multiple Species Conservation Plan was  
3 also examined<sup>65</sup>. Three large parcels of equivalent chaparral have been purchased  
4 since 2000:

5  
6  
7

<b>Name and Location</b>	<b>Acres</b>	<b>Purchase Date</b>	<b>Cost</b>	<b>Cost/Acre</b>
Hollenbeck Canyon, Daley Ranch, Ph I	312.5	9/7/2000	\$2,000,000.00	\$6,400.00
Iron Mountain, Boulder Oaks	1,215.00	9/26/2003	\$4,410,000.00	\$3,629.63
Iron Mountain, Ramona Serena/ Barnett Ranch	716.5	1/25/2002	\$4,440,000.00	\$6,196.79

8

9 It can be seen that the price of preserve-quality parcels is higher than that of  
10 average lands and that currently the cost of replacement is around a factor of ten  
11 less than restoration.

12

13 **Q. Are there circumstances that would make restoration necessary**  
14 **rather than replacement?**

15 **A.** Yes. It may be that as population expands and large parcels of suitable  
16 habitat become rarer, the value of these parcels will increase up to the ceiling set  
17 by restoration.

18 It may also happen that certain preserves are irreplaceable because they contain  
19 unique habitats. The EIR should determine if this is applicable to any proposed  
20 SPL routes.

---

<sup>65</sup> Appendix H, Section H2.6

1  
2 **14. OTHER WILDLAND FIRE ISSUES TO BE REVIEWED**  
3

4 **Q. Are there other analyses of wildland fire issues that should be**  
5 **conducted as part of the EIR review process?**

6 **A. Yes, a number of additional and supplemental analyses need to be**  
7 **conducted as part of the EIR.** Aside from those already mentioned, these include,  
8 but are not limited to, the following:

- 9 1. The MGRA analysis to this point has concentrated only on the original  
10 proposed SPL route, and the SWPL route for the sake of comparison. All  
11 routes being considered need to be analyzed using a route hazard analysis  
12 method in the EIR, such as that illustrated with by the  
13 “Route\_Analysis\_SPL.xls<sup>66</sup>” file. This method allows the relative hazards  
14 along each segment of the line to be compared and analyzed. The results  
15 should also be presented in a format such as that of the Route Analysis  
16 spreadsheets, which allow users without specialized software or tools to  
17 examine correlations between factors along the route. This is critical,  
18 because certain hazards occur when various conditions occur in  
19 conjunction. Some of these are described below.
- 20 2. Santa Ana wind hazard maps, created from NWS computer models by  
21 averaging over recent events, should be generated as part of the EIR. This  
22 is described in more detail in Appendix F.
- 23 3. A fire hazard metric applicable to power line fires should be created as  
24 part of the EIR. This should take into account locational dependencies of  
25 vegetation fuel load, slope, and Santa Ana wind threat. This should be  
26 included in the Route Analysis for all routes under consideration.

---

<sup>66</sup> Attached as Route\_Analysis\_SPL.xls

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 48 of 67**

- 1           4. Routes of current transmission lines within the SDG&E service area  
2           should be similarly analyzed via Route Analysis hazard mapping as part of  
3           the EIR in order to gauge the applicability of historical fire information to  
4           predicting future fires. Future fire rates should be predicted based on this  
5           more comprehensive information.
- 6           5. The EIR should address what the maximum strength of an expected Santa  
7           Ana event will be within the lifetime of the project, taking into account  
8           possible climate change effects.
- 9           6. The correlation of earthquake risk and vegetation should be considered as  
10          part of the EIR.

11  
12          **Q.     What is the relationship between earthquake and wildland fire?**

13          **A.**     If an earthquake causes faulting or structural failure of live lines, then  
14          arcing may occur and hot material may be ejected. If this falls onto vegetation it  
15          can cause a fire.

16  
17          **Q.     Aren't transmission lines engineered to withstand earthquakes?**

18          **A.**     The best industry practice, according to sources cited in SDG&E's  
19          response to data request MGRA-35, is to consider wind and ice loading to be the  
20          limiting case for line stress, usually exceeding that for seismic stresses. Hence  
21          seismic vibrations are typically not modeled. However, El-Attar<sup>67</sup> has calculated  
22          seismic loading for transmission lines using both computer simulation and  
23          analytical techniques, and has concluded that in areas where wind and ice load are  
24          small, such as Southern California, that seismic loadings can exceed design limits

---

<sup>67</sup> El-Attar, Mohamed Mohsen; Nonlinear dynamics and seismic response of power transmission lines;  
PhD Dissertation, MCMASTER UNIVERSITY; 1997

**PHASE 1 DIRECT TESTIMONY OF THE  
MUSSEY GRADE ROAD ALLIANCE  
A.06-08-010**

**Page 49 of 67**

1 for wind and ice load. This can occur for earthquake horizontal accelerations as  
2 small as 0.35g<sup>68</sup> (g is the acceleration equivalent to earth's gravity).

3

4 **Q. Where along the line route might we expect such accelerations?**

5 **A.** The greatest seismic hazard to the line itself will occur along the desert  
6 segment of the route. Failures and faults in this region would impact reliability  
7 and lifeline capabilities for the SDG&E service area, but would not create a  
8 substantial wildland fire risk. According to USGS seismic hazard maps<sup>69</sup>,  
9 however, a substantial portion of the proposed SPL route, specifically its  
10 "northern loop" including the proposed central substation, are at 10% risk for  
11 exceeding .3-.4g acceleration within the lifetime of the project. This area also  
12 happens to have the most hazardous fuel regions along the route. It may be  
13 assumed that in the aftermath of a serious earthquake, emergency services will be  
14 overtaxed and unable to effectively suppress a wildland fire until external  
15 resources arrive, creating the threat of conflagration.

16

17 **Q. How should the earthquake issue be addressed?**

18 **A.** The EIR should conduct a thorough review of El-Attar's calculations as  
19 applied to the planned SPL construction techniques and materials, including if  
20 appropriate seismic modeling of the planned structures. Included in the Route  
21 Analysis should be peak accelerations, and a metric should be calculated that  
22 takes into account vegetation and maximum acceleration in order to define a  
23 hazard zone. Finally, if the results require re-engineering the SPL in hazardous  
24 areas, the added costs of more robust construction should be added to the  
25 cost/benefit analysis.

---

<sup>68</sup> El-Attar, pp. 79-80, 114-115

<sup>69</sup> Rukstales, Kenneth S.(compiler); ATLAS.ATLAS\_SEISMIC\_HAZARD (digital vector file); US Geological Survey, National Seismic Hazard Mapping Project; Reston, VA; 2002; available from <http://www.landfire.gov>

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

**15. OTHER ISSUES TO BE REVIEWED**

**Q. Are there any other issues relating to economics or reliability that MGRA wishes to raise?**

**A.** Yes. One point raised by MGRA and answered by SDG&E in its response to data request MGRA-37 illustrates a fundamental issue with reliability. One of the main arguments used for SPL is that it provides redundancy for the SWPL transmission line. However, both SWPL and SPL originate at a common location: the Imperial Valley substation. This creates a “single point of failure” that could put the entire supply to San Diego County at risk. SDG&E has at our request modeled the effect of the loss of the Imperial Valley substation under 2010 conditions, for both summer load and light winter load. They found that under summer conditions, the removal of all lines leading to the Imperial Valley substation might cause a cascading blackout. The Imperial Valley is in an extreme seismic hazard zone, and recent work suggests that a large earthquake along the southern San Andreas is overdue and not unlikely within the lifetime of the project<sup>70</sup>. Furthermore, this exposes our electrical grid to a terror attack on a single point target. This lack of redundancy seems counter to the spirit of reliability.

**Q. Does this conclude the MGRA testimony?**

**A.** Yes, this concludes the MGRA testimony.

---

<sup>70</sup> Fialko, Yuri; Interseismic strain accumulation and the earthquake potential on the southern San Andreas Fault; Nature; v. 441; pp. 968-971; 22 June, 2006

## **CERTIFICATE OF SERVICE**

I hereby certify that I have served, by electronic mail, a copy of the foregoing Phase I Direct Testimony of the Mussey Grade Road Alliance Fire Analysis – Economic Impacts to each party in Docket No. A.06-08-010.

Executed on May 31, 2006 at Ramona, California.

**/s/ Diane Conklin**

Diane Conklin, Spokesperson  
Mussey Grade Road Alliance  
P.O. Box 683  
Ramona, CA 92065

**Appearance**

SARA FELDMAN  
CA STATE PARKS FOUNDATION  
714 W. OLYMPIC BLVD., SUITE 717  
LOS ANGELES, CA 90015

THOMAS A. BURHENN  
SOUTHERN CALIFORNIA EDISON  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CA 91770

DON WOOD SR.  
PACIFIC ENERGY POLICY CENTER  
4539 LEE AVENUE  
LA MESA, CA 91941

DIANA LINSDAY  
ANZA-BORREGO FOUNDATION & INSTITUTE  
PO BOX 2001  
BORREGO SPRINGS, CA 92004

MICHAEL L. WELLS  
CALIFORNIA DEPARTMENT OF PARKS & RECREATION  
200 PALM CANYON DRIVE  
BORREGO SPRINGS, CA 92004

SCOT MARTIN  
PO BOX 1549  
BORREGO SPRINGS, CA 92004

DAVID LLOYD  
ATTORNEY AT LAW  
CABRILLO POWER I, LLC  
4600 CARLSBAD BLVD.  
CARLSBAD, CA 92008

CONNIE BULL  
24572 RUTHERFORD ROAD  
RAMONA, CA 92065

DIANE J. CONKLIN  
MUSSEY GRADE ROAD ALLIANCE  
PO BOX 683  
RAMONA, CA 92065

ELIZABETH EDWARDS  
RAMONA VALLEY VINEYARD ASSOCIATION  
26502 HIGHWAY 78  
RAMONA, CA 92065

PAM WHALEN  
24444 RUTHERFORD ROAD  
RAMONA, CA 92065

MICHAEL PAGE  
17449 OAK HOLLOW ROAD  
RAMONA, CA 92065-6758

HEIDI FARKASH  
JOHN & HEIDI FARKASH TRUST  
COMM  
PO BOX 576  
RANCHO SANTA FE, CA 92067

DENIS TRAFECANTY  
COMMUNITY OF SANTA YSABEL & RELATED  
PO BOX 305  
SANTA YSABEL, CA 92070

MARY ALDERN  
COMMUNITY ALLIANCE FOR SENSIBLE ENERGY  
PO BOX 321  
WARNER SPRINGS, CA 92086

E. GREGORY BARNES  
ATTORNEY AT LAW  
SAN DIEGO GAS & ELECTRIC COMPANY  
101 ASH STREET, HQ 13D  
SAN DIEGO, CA 92101

FREDERICK M. ORTLIEB  
OFFICE OF CITY ATTORNEY  
CITY OF SAN DIEGO  
1200 THIRD AVENUE, SUITE 1100  
SAN DIEGO, CA 92101

MICHAEL P. CALABRESE  
CITY ATTORNEY'S OFFICE  
1200 THIRD AVENUE, SUITE 1100  
SAN DIEGO, CA 92101

DONALD C. LIDDELL  
ATTORNEY AT LAW  
DOUGLASS & LIDDELL  
2928 2ND AVENUE  
SAN DIEGO, CA 92103

MICHAEL SHAMES  
ATTORNEY AT LAW  
UTILITY CONSUMERS' ACTION NETWORK  
3100 FIFTH AVENUE, SUITE B  
SAN DIEGO, CA 92103

PAUL BLACKBURN  
SIERRA CLUB, SAN DIEGO CHAPTER  
ELECTRI  
3820 RAY STREET  
SAN DIEGO, CA 92104

EDWARD GORHAM  
WESTERNERS INCENSED BY WRECKLESS  
4219 LOMA RIVIERA LANE  
SAN DIEGO, CA 92110

KEVIN O'BEIRNE  
SAN DIEGO GAS & ELECTRIC COMPANY  
8330 CENTURY PARK COURT, CP32D  
SAN DIEGO, CA 92123

HARVEY PAYNE  
RANCHO PENASQUITOS CONCERNED CITIZENS  
13223 - 1 BLACK MOUNTAIN ROAD, 264  
SAN DIEGO, CA 92129

KEITH RITCHEY  
POWERLINK ISSUES MANAGER  
8744 CREEKWOOD LANE  
LLP  
SAN DIEGO, CA 92129

JOHN W. LESLIE  
ATTORNEY AT LAW  
LUCE, FORWARD, HAMILTON & SCRIPPS,  
11988 EL CAMINO REAL, SUITE 200  
SAN DIEGO, CA 92130

JOETTA MIHALOVICH  
11705 ALDERCREST POINT  
SAN DIEGO, CA 92131

DAVID HOGAN  
CENTER FOR BIOLOGICAL DIVERSITY  
PO BOX 7745



SAN DIEGO, CA 92167

CARRIE DOWNEY  
HORTON KNOX CARTER & FOOTE  
895 BROADWAY  
ELCENTRO, CA 92243

PATRICIA C. SCHNIER  
14575 FLATHEAD RD.  
APPLE VALLEY, CA 92307

BILLY BLATTNER  
SAN DIEGO GAS & ELECTRIC COMPANY  
601 VAN NESS AVENUE, SUITE 2060  
SAN FRANCISCO, CA 94102

MICHEL PETER FLORIO  
ATTORNEY AT LAW  
THE UTILITY REFORM NETWORK (TURN)  
711 VAN NESS AVENUE, SUITE 350  
SAN FRANCISCO, CA 94102

OSA L. WOLFF  
ATTORNEY AT LAW  
SHUTE, MIHALY & WEINBERGER, LLC  
396 HAYES STREET  
SAN FRANCISCO, CA 94102

JOE COMO  
CALIF PUBLIC UTILITIES COMMISSION  
LEGAL DIVISION  
ROOM 5033  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

NICHOLAS SHER  
CALIF PUBLIC UTILITIES COMMISSION  
LEGAL DIVISION  
ROOM 4007  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

JUSTIN AUGUSTINE  
THE CENTER FOR BIOLOGICAL DIVERSITY  
1095 MARKET ST., SUITE 511  
SAN FRANCISCO, CA 94103

NORMAN J. FURUTA  
ATTORNEY AT LAW  
FEDERAL EXECUTIVE AGENCIES  
1455 MARKET ST., SUITE 1744  
SAN FRANCISCO, CA 94103-1399

RORY COX  
311 CALIFORNIA STREET, SUITE 650  
SAN FRANCISCO, CA 94104

BRIAN T. CRAGG  
ATTORNEY AT LAW  
LLP  
GOODIN MACBRIDE SQUERI RITCHIE & DAY  
505 SANSOME STREET, SUITE 900  
SAN FRANCISCO, CA 94111

VIDHYA PRABHAKARAK  
GOODIN MACBRIDE SQUERI DAY & LAMPREY  
505 SANSOME STREET, SUITE 900  
SAN FRANCISCO, CA 94111

VIDHYA PRABHAKARAN  
GOODIN, MACBRIDE, SQUERI, RITCHIE, DAY

WILLIAM F. DIETRICH  
ATTORNEY AT LAW

505 SANSOME STREET, SUITE 900  
SAN FRANCISCO, CA 94111

DIETRICH LAW  
2977 YGNACIO VALLEY ROAD, 613  
WALNUT CREEK, CA 94598-3535

DAVID KATES  
DAVID MARK AND COMPANY  
3510 UNOCAL PLACE, SUITE 200  
OPERATOR  
SANTA ROSA, CA 95403-5571

JUDITH B. SANDERS  
ATTORNEY AT LAW  
CALIFORNIA INDEPENDENT SYSTEM  
  
151 BLUE RAVINE ROAD  
FOLSOM, CA 95630

BRADLY S. TORGAN  
ATTORNEY AT LAW  
CALIFORNIA DEPT. OF PARKS & RECREATION  
1416 NINTH STREET, ROOM 1404-06  
SACRAMENTO, CA 95814

JEFFERY D. HARRIS  
ATTORNEY AT LAW  
ELLISON, SCHNEIDER & HARRIS LLP  
2015 H STREET  
SACRAMENTO, CA 95814

KAREN NORENE MILLS  
ATTORNEY AT LAW  
CALIFORNIA FARM BUREAU FEDERATION  
2300 RIVER PLAZA DRIVE  
SACRAMENTO, CA 95833

KEVIN LYNCH  
PPM ENERGY INC.  
1125 NW COUCH ST., SUITE 700  
PORTLAND, OR 97209

***Information Only***

JUILE B. GREENISEN  
LATHAM & WATKINS LLP  
SUITE 1000  
555 ELEVENTH STREET, NW  
WASHINGTON, DC 20004-1304

MICHAEL J. GERGEN  
LATHAM & WATKINS LLP  
SUITE 1000  
555 ELEVENTH STREET, NW  
WASHINGTON, DC 20004-1304

MICHAEL J. THOMPSON  
WRIGHT & TALISMAN, PC  
1200 G STREET, NW, SUITE 600  
WASHINGTON, DC 20005

HENRY MARTINEZ  
LADWP  
111 N. HOPE ST., ROOM 921  
LOS ANGELES, CA 90012

LORRAINE A. PASKETT  
LADWP  
111 N. HOWARD ST., ROOM 1536  
LOS ANGELES, CA 90012

RANDY S. HOWARD  
LOS ANGELES DEPT. OF WATER AND POWER  
111 NORTH HOPE STREET, ROOM 921  
LOS ANGELES, CA 90012

CLAY E. FABER  
SOUTHERN CALIFORNIA GAS COMPANY  
555 WEST FIFTH STREET, GT-14D6  
LOS ANGELES, CA 90013

ARTHUR FINE  
MITCHELL SILBERBERG & KNUPP LLP  
11377 W. OLYMPIC BLVD.  
LOS ANGELES, CA 90064-1683

CASE ADMINISTRATION  
SOUTHERN CALIFORNIA EDISON COMPANY  
LAW DEPARTMENT  
2244 WALNUT GROVE AVENUE  
G01  
ROSEMEAD, CA 91770

DARELL HOLMES  
TRANSMISSION MANAGER  
SOUTHERN CALIFORNIA EDISON  
2244 WALNUT GROVE AVE, 238M, QUADB,  
ROSEMEAD, CA 91770

DONNA TISDALE  
BOULEVARD SPONSOR GROUP  
PO BOX 1272  
BOULEVARD, CA 91905

JOHN GRISAFI  
PO BOX 310125  
GUATAY, CA 91931

MATTHEW JUMPER  
SAN DIEGO INTERFAITH HOUSING FOUNDATION  
7956 LESTER AVE  
LEMON GROVE, CA 91945

REBECCA PEARL  
POLICY ADVOCATE, CLEAN BAY CAMPAIGN  
ENVIRONMENTAL HEALTH COALITION  
401 MILE OF CARS WAY, STE. 310  
NATIONAL CITY, CA 91950

LINDA A. CARSON  
EXECUTIVE DIRECTOR  
ANZA-BORREGO FOUNDATION  
PO BOX 2001  
BORREGO SPRINGS, CA 92004

BOB & MARGARET BARELMANN  
6510 FRANCISCAN ROAD  
CARLSBAD, CA 92011

DAVE DOWNEY  
NORTH COUNTY TIMES  
207 E. PENNSYLVANIA AVENUE  
ESCONDIDO, CA 92025

PAT/ALBERT BIANEZ  
1223 ARMSTRONG CIRCLE  
ESCONDIDO, CA 92027

WALLY BESUDEN  
PRESIDENT  
SPANGLER PEAK RANCH, INC  
PO BOX 1959  
ESCONDIDO, CA 92033

DAVID W. CAREY  
DAVID CAREY & ASSOCIATES, INC.  
PO BOX 2481  
JULIAN, CA 92036

LAUREL GRANQUIST  
PO BOX 2486  
JULIAN, CA 92036

MARTHA BAKER  
VOLCAN MOUNTAIN PRESERVE FOUNDATION  
PO BOX 1625  
JULIAN, CA 92036

JOHN RAIFSNIDER  
PO BOX 121  
JULIAN, CA 92036-0121

BRIAN KRAMER  
PO BOX 516  
JULIAN, CA 92036-0516

NANCY PARINELLO  
PO BOX 516  
JULIAN, CA 92036-0516

PAUL RIDGWAY  
3027 LAKEVIEW DR.  
PO BOX 1435  
JULIAN, CA 92036-1435

DAVID VOSS  
502 SPRINGFIELD AVENUE  
OCEANSIDE, CA 92057

SCOTT KARDEL  
PALOMAR OBSERVATORY  
PO BOX 200  
PALOMAR MOUNTAIN, CA 92060

CAROLYN A. DORROH  
RAMONA COMMUNITY PLANNING GROUP  
17235 VOORHES LANE  
RAMONA, CA 92065

CHRISTOPHER P. JEFFERS  
24566 DEL AMO ROAD  
RAMONA, CA 92065

LARA LOPEZ  
16828 OPEN VIEW RD  
RAMONA, CA 92065

MARY KAY FERWALT  
24569 DEL AMO ROAD  
RAMONA, CA 92065

PETER SCHULTZ  
OLD JULIAN CO.  
PO BOX 2269  
RAMONA, CA 92065

PHILLIP & ELIANE BREEDLOVE  
1804 CEDAR STREET  
RAMONA, CA 92065

WILLIAM TULLOCH  
28223 HIGHWAY 78  
RAMONA, CA 92065

CAROLYN MORROW  
GOLIGHTLY FARMS  
36255 GRAPEVINE CANYON ROAD  
RANCHITA, CA 92066

JOSEPH RAUH  
RANCHITA REALTY  
37554 MONTEZUMA VALLEY RD  
RANCHITA, CA 92066

STEVE/CAROLYN ESPOSITO  
37784 MONTEZUMA VALLEY ROAD  
RANCHITA, CA 92066

BONNIE GENDRON  
4812 GLENSIDE ROAD  
SANTA YSABEL, CA 92070

GLENDA KIMMERLY  
PO BOX 305  
SANTA YSABEL, CA 92070

GLENN E. DROWN  
PO BOX 330  
SANTA YSABEL, CA 92070

JOHN&PHYLLIS BREMER  
PO BOX 510  
SANTA YSABEL, CA 92070

RON WEBB  
PO BOX 375  
SANTA YSABEL, CA 92070

DAN PERKINS  
ENERGY SMART HOMES  
983 PHILLIPS ST.  
VISTA, CA 92083

KARL HIGGINS  
PRESIDENT  
HIGGINS & ASSOCIATES  
1517 ROMA DRIVE  
VISTA, CA 92083

WILLIE M. GATERS  
1295 EAST VISTA WAY  
VISTA, CA 92084

ABBAS M. ABED  
ASSOCIATE DIRECTOR  
NAVIGANT CONSULTING, INC.  
402 WEST BROADWAY, SUITE 400  
SAN DIEGO, CA 92101

SUSAN FREEDMAN  
SENIOR REGIONAL ENERGY PLANNER  
SAN DIEGO ASSOCIATION OF GOVERNMENTS  
401 B STREET, SUITE 800  
SAN DIEGO, CA 92101

JIM BELL  
4862 VOLTAIRE ST.  
SAN DIEGO, CA 92107

STEPHEN ROGERS  
1340 OPAL STREET  
SN DIEGO, CA 92109

EPIC INTERN  
EPIC/USD SCHOOL OF LAW  
5998 ALCALA PARK  
SAN DIEGO, CA 92110

SCOTT J. ANDERS  
RESEARCH/ADMINISTRATIVE CENTER  
UNIVERSITY OF SAN DIEGO - LAW  
5998 ALCALA PARK  
SAN DIEGO, CA 92110

CRAIG ROSE  
THE SAN DIEGO UNION TRIBUNE  
PO BOX 120191S  
SAN DIEGO, CA 92112-0191

GEORGE COURSER  
3142 COURSER AVENUE  
SAN DIEGO, CA 92117

CENTRAL FILES  
SAN DIEGO GAS & ELECTRIC  
8330 CENTURY PARK COURT, CP31E  
ENERGY  
SAN DIEGO, CA 92123

IRENE STILLINGS  
EXECUTIVE DIRECTOR  
CALIFORNIA CENTER FOR SUSTAINABLE  
8520 TECH WAY, SUITE 110  
SAN DIEGO, CA 92123

JENNIFER PORTER  
POLICY ANALYST  
CALIFORNIA CENTER FOR SUSTAINABLE ENERGY  
ENERGY  
8690 BALBOA AVENUE, SUITE 100  
SAN DIEGO, CA 92123

SEPHRA A. NINOW  
POLICY ANALYST  
CALIFORNIA CENTER FOR SUSTAINABLE  
8690 BALBOA AVENUE, SUITE 100  
SAN DIEGO, CA 92123

TOM BLAIR  
ENERGY ADMINISTRATOR  
CITY OF SAN DIEGO  
9601 RIDGEHAVEN COURT, SUITE 120  
SAN DIEGO, CA 92123-1636

DAHVIA LOCKE  
ENIRONMENTAL RESOURCE MANAGER  
COUNTY OF SAN DIEGO  
5201 RUFFIN ROAD, SUITE B  
SAN DIEGO, CA 92123-1666

JALEH (SHARON) FIROOZ, P.E.  
ADVANCED ENERGY SOLUTIONS  
17114 TALLOW TREE LANE  
SAN DIEGO, CA 92127

EILEEN BIRD  
12430 DORMOUSE ROAD  
SAN DIEGO, CA 92129

LYNDA KASTOLL  
REALTY SPECIALIST  
BUREAU OF LAND MANAGEMENT  
EL CENTRO FIELD OFFICE  
1661 SOUTH 4TH STREET  
EL CENTRO, CA 92243

THOMAS ZALE  
BUREAU OF LAND MANAGEMENT  
1661 SO. 4TH STREET  
EL CENTRO, CA 92243

SUZANNE WILSON  
PO BOX 798  
IDYLLWILD, CA 92549

LOUIS NASTRO  
PO BOX 942896  
SACRAMENTO, CA 92860-0001

BRUCE FOSTER  
VICE PRESIDENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
601 VAN NESS AVENUE, STE. 2040  
SAN FRANCISCO, CA 94102

DIANE I. FELLMAN  
ATTORNEY AT LAW  
FPL ENERGY, LLC  
234 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102

SHERIDAN PAUKER  
SHUTE, MIHALY & WEINBERGER LLP  
ENERGY  
396 HAYES STREET  
SAN FRANCISCO, CA 94102

AARON QUINTANAR  
RATE PAYERS FOR AFFORDABLE CLEAN  
311 CALIFORNIA STREET, STE 650  
SAN FRANCISCO, CA 94104

BREWSTER BIRDSALL  
ASPEN ENVIRONMENTAL GROUP  
235 MONTGOMERY STREET, SUITE 935  
SAN FRANCISCO, CA 94104

JASON YAN  
PACIFIC GAS AND ELECTRIC COMPANY  
77 BEALE STREET, MAIL CODE B13L  
SAN FRANCISCO, CA 94105

MICHAEL S. PORTER  
PACIFIC GAS AND ELECTRIC COMPANY  
77 BEALE ST., MAIL CODE 13L RM 1318  
SAN FRANCISCO, CA 94105

CALIFORNIA ENERGY MARKETS  
517 - B POTRERO AVENUE  
SAN FRANCISCO, CA 94110

JULIE L. FIEBER  
FOLGER LEVIN & KAHN LLP  
275 BATTERY STREET, 23RD FLOOR

RICHARD W. RAUSHENBUSH  
ATTORNEY AT LAW  
LATHAM & WATKINS LLP

SAN FRANCISCO, CA 94111

505 MONTGOMERY STREET, SUITE 2000  
SAN FRANCISCO, CA 94111

DAVID T. KRASKA  
ATTORNEY AT LAW  
PACIFIC GAS AND ELECTRIC COMPANY  
PO BOX 7442  
SAN FRANCISCO, CA 94120

JOSEPH M. PAUL  
SENIOR CORPORATE COUNSEL  
DYNEGY, INC.  
2420 CAMINO RAMON, SUITE 215  
SAN RAMON, CA 94583

HENRY ZAININGER  
ZAININGER ENGINEERING COMPANY, INC.  
1718 NURSERY WAY  
PLEASANTON, CA 94588

PHILIPPE AUCLAIR  
11 RUSSELL COURT  
WALNUT CREEK, CA 94598

J.A. SAVAGE  
CALIFORNIA ENERGY CIRCUIT  
3006 SHEFFIELD AVE  
OAKLAND, CA 94602

MRW & ASSOCIATES, INC.  
1814 FRANKLIN STREET, SUITE 720  
OAKLAND, CA 94612

DAVID MARCUS  
PO BOX 1287  
BERKELEY, CA 94701

KEN BAGLEY  
R.W. BECK  
14635 N. KIERLAND BLVD., SUITE 130  
SOCTTSDALE, AZ 95254

W. KENT PALMERTON  
WK PALMERTON ASSOCIATES, LLC  
2106 HOMEWOOD WAY, SUITE 100  
CARMICHAEL, CA 95608

LEGAL & REGULATORY DEPARTMENT  
CALIFORNIA ISO  
151 BLUE RAVINE ROAD  
FOLSOM, CA 95630

DAVID BRANCHCOMB  
BRANCHCOMB ASSOCIATES, LLC  
9360 OAKTREE LANE  
ORANGEVILLE, CA 95662

PAUL G. SCHEUERMAN  
SHEUERMAN CONSULTING  
3915 RAWHIDE RD.  
ROCKLIN, CA 95677

LON W. HOUSE  
WATER & ENERGY CONSULTING  
4901 FLYING C RD.

DARRELL FREEMAN  
1304 ANTRIM DR.  
ROSEVILLE, CA 95747



CAMERON PARK, CA 95682

ANDREW B. BROWN  
ATTORNEY AT LAW  
ELLISON, SCHNEIDER & HARRIS, LLP  
2015 H STREET  
SACRAMENTO, CA 95814

AUDRA HARTMANN  
DYNEGY, INC.  
980 NINTH STREET, SUITE 2130  
SACRAMENTO, CA 95814

KELLIE SMITH  
SENATE ENERGY/UTILITIES & COMMUNICATION  
STATE CAPITOL, ROOM 4038  
SACRAMENTO, CA 95814

KEVIN WOODRUFF  
WOODRUFF EXPERT SERVICES, INC.  
1100 K STREET, SUITE 204  
SACRAMENTO, CA 95814

RICHARD LAUCKHART  
GLOBAL ENERGY  
2379 GATEWAY OAKS DRIVE, SUITE 200  
SACRAMENTO, CA 95833

G. ALAN COMNES  
CABRILLO POWER I LLC  
3934 SE ASH STREET  
PORTLAND, OR 97214

DANIEL SUURKASK  
WILD ROSE ENERGY SOLUTIONS, INC.  
430 8170 50TH STREET  
EDMONTON, AB T6B 1E6  
CANADA

**State Service**

MARCUS NIXON  
CALIF PUBLIC UTILITIES COMMISSION  
PUBLIC ADVISOR OFFICE  
ENERGY  
320 WEST 4TH STREET SUITE 500  
LOS ANGELES, CA 90013

JACK BURKE  
LEGISLATIVE AFFAIRS MANAGER  
CALIFORNIA CENTER FOR SUSTAINABLE  
8690 BALBOA AVE., SUITE 100  
SAN DIEGO, CA 92123

BILLIE C. BLANCHARD  
CALIF PUBLIC UTILITIES COMMISSION  
ENERGY DIVISION  
AREA 4-A  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

DAVID NG  
CALIF PUBLIC UTILITIES COMMISSION  
EXECUTIVE DIVISION  
ROOM 5207  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

DONALD R. SMITH  
CALIF PUBLIC UTILITIES COMMISSION  
ELECTRICITY RESOURCES & PRICING BRANCH  
ROOM 4209  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

KEITH D WHITE  
CALIF PUBLIC UTILITIES COMMISSION  
RATEMAKING BRANCH  
AREA 4-A  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

LAURENCE CHASET  
CALIF PUBLIC UTILITIES COMMISSION  
LEGAL DIVISION  
ROOM 5131  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

ROBERT ELLIOTT  
CALIF PUBLIC UTILITIES COMMISSION  
ENERGY DIVISION  
AREA 4-A  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

SCOTT CAUCHOIS  
CALIF PUBLIC UTILITIES COMMISSION  
ELECTRICITY RESOURCES & PRICING BRANCH  
BRANCH  
ROOM 4209  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

SCOTT LOGAN  
CALIF PUBLIC UTILITIES COMMISSION  
ELECTRICITY RESOURCES & PRICING  
ROOM 4209  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

STEVEN A. WEISSMAN  
CALIF PUBLIC UTILITIES COMMISSION  
DIVISION OF ADMINISTRATIVE LAW JUDGES  
ROOM 5107  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

TERRIE D. PROSPER  
CALIF PUBLIC UTILITIES COMMISSION  
EXECUTIVE DIVISION  
ROOM 5301  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

TRACI BONE  
CALIF PUBLIC UTILITIES COMMISSION  
LEGAL DIVISION  
ROOM 5206  
505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3214

SUSAN LEE  
ASPEN ENVIRONMENTAL GROUP  
235 MONTGOMERY STREET, SUITE 935  
SAN FRANCISCO, CA 94104

CLARE LAUFENBERG  
CALIFORNIA ENERGY COMMISSION  
1516 NINTH STREET, MS 46  
SACRAMENTO, CA 95814

MARC PRYOR  
CALIFORNIA ENERGY COMMISSION  
1516 9TH ST, MS 20  
SACRAMENTO, CA 95814

THOMAS FLYNN  
CALIF PUBLIC UTILITIES COMMISSION  
ENERGY RESOURCES BRANCH  
770 L STREET, SUITE 1050  
SACRAMENTO, CA 95814

JUDY GRAU  
CALIFORNIA ENERGY COMMISSION  
1516 NINTH STREET MS-46  
SACRAMENTO, CA 95814-5512

TOM MURPHY  
VP., SACRAMENTO OPERATIONS  
ASPEN ENVIRONMENTAL GROUP  
8801 FOLSOM BLVD., SUITE 290  
SACRAMENTO, CA 95826